



STATE OF WISCONSIN
Department of Safety and Professional Services
1400 East Washington Avenue
Madison WI 53703

Mail to:
PO Box 8368
Madison WI 53708-8368

E-mail: dsps@wisconsin.gov
Web: <http://dsps.wi.gov>
Phone: 608-266-2112

Governor Scott Walker Secretary Dave Ross

UNIFORM DWELLING CODE COUNCIL MEETING
Room 121A, 1400 East Washington Avenue, Madison
Contact: Jeff Grothman (608) 266-2112
July 21, 2015

The following agenda describes the issues that the Council plans to consider at the meeting. At the time of the meeting, items may be removed from the agenda. Please consult the resulting meeting minutes for a description of the recommendations of the Council.

AGENDA

9:00 A.M.

CALL TO ORDER – ROLL CALL

- A) Adoption of Agenda (1)**
- B) Approval of Minutes of April 29, 2015 (2-3)**
- C) Department Update**
 - 1. Consideration of Clearinghouse Rule 15-041 and UDC Update (4-43)**
 - a. ResCheck Update**
 - b. Discussion of Change from IECC 2006 to IECC 2009 Energy Requirements**
 - 2. Act 49 – Camping Units – Rules Discussion**
- D) Public Comments**
- E) Future Business**
- F) Adjournment**

**UNIFORM DWELLING COUNCIL
MEETING MINUTES
April 29, 2015**

PRESENT: Amy Bliss, Michael Coello, Abe Degnan (*arrived at 9:05 a.m.*), Steven Gryboski, Jesse Jerabek, Peter Krabbe, Mike Marthaler, Scott Satula, Mary Schroeder, Brian Wert

STAFF: Jeff Grothman, Policy Director; Dan Smith, Rules Coordinator; Steve Dobratz, Integrated Services Section Chief; Duane Hubeler, UDC Engineering Consultant; and Taylor Thompson, Bureau Assistant

CALL TO ORDER

Michael Coello, Chair, called the meeting to order at 9:02 a.m. A quorum of ten (10) members was confirmed.

ADOPTION OF AGENDA

MOTION: Brian Wert moved, seconded by Scott Satula, to adopt the agenda as published. Motion carried unanimously.

APPROVAL OF MINUTES

MOTION: Amy Bliss moved, seconded by Mary Schroeder, to approve the minutes of March 10, 2015 as published. Motion carried unanimously.

**DISCUSSION REGARDING EMAIL NOTIFICATION FOR
320.10 (4)(A) 1. AND 320.10 (4)(A) 2**

MOTION: Brian Wert moved, seconded by Scott Satula, to change 320.10(4)(a)1, and 320.10(4)(a)2 to add language to allow the option of electronic notification and to allow Department staff to work on draft language. Motion carried unanimously.

Brian Wert left the room.

MOTION: Steve Gryboski moved, seconded by Amy Bliss, to rescind the motion regarding email notification for 320.10(4)(a)1, and 320.10(4)(a)2. Motion carried. *Brian Wert not present.*

MOTION: Scott Satula moved, seconded by Abe Degnan, to change 320.10(4)(a)1, and 320.10(4)(a)2 to add language to allow the option of electronic notification and to allow Department staff to work on draft language. Motion carried. *Brian Wert not present.*

DISCUSSION OF CRAWLSPACE VENTILATION

MOTION: Jesse Jerabek moved, seconded by Mary Schroeder, to remove paragraph 3 under SPS 322.34, in addition, Department staff will make modifications where needed in paragraph 4. Motion carried unanimously.

DISCUSSION OF WINDOWS ABOVE GARAGES

MOTION: Abe Degnan moved, seconded by Jesse Jerabek, to add an exception to SPS 321.05, paragraph a, adding habitable rooms above garages. Motion carried. *Scott Satula voted against.*

ADJOURNMENT

MOTION: Scott Satula moved, seconded by Mary Schroeder, to adjourn the meeting. Motion carried unanimously.

The meeting adjourned at 1:31 p.m.

DRAFT

STATE OF WISCONSIN
Department of Safety and Professional Services

IN THE MATTER OF RULEMAKING : PROPOSED ORDER OF THE
PROCEEDINGS BEFORE THE : DEPARTMENT OF SAFETY AND
DEPARTMENT OF SAFETY AND : PROFESSIONAL SERVICES
PROFESSIONAL SERVICES : ADOPTING RULES
: (CLEARINGHOUSE RULE 15-041)

PROPOSED ORDER

An order of the Department of Safety and Professional Services to repeal SPS 320.07 (34m), (67), and (67m), 320.085, 320.09 (5) (d), 320.24 (2) Table 320.24–8, 321.02 (3) (g) 1., 321.125 (3) (a) 2. (Note) and (b), 321.126, 321.28 (3) (a) (Note) [2] and (b), 322.01 (3) (Note), 322.20 (6), 322.31 Table 322.31–4 (Note), and 322.38 (2) (c) 4. (Note);

to renumber SPS 321.02 (1) (b) 1. Table 321.02, 321.10 (2) (f), 321.25 (3) (intro.), (a), and (b), 322.01 (3), 322.32 (1), 322.32 (9), 323.04 (4), 323.045 (5) (a), 323.045 (6) (a), and 323.14 (1);

to renumber and amend SPS 320.24 (2) Table 320.24–2, 321.02 (1) (d), (title), and (Note), 321.04 (3) (a) 4. c. and (b) 1., and (4) (c) 1. and 2., 321.045 (4) (c), 321.05 (2) (a) and (3) (intro.) to (d) and (e), 321.06, 321.12, 321.15 (1) (e) 2., 321.28 (7) (c), 322.33 (1), 322.38 (1) (b), 323.045 (6) (a) (intro.), 323.14 (2) (a), 325.01 and SPS 320 to 325 Appendix, Minimum Fastener Schedule Table;

to consolidate, renumber, and amend 321.02 (3) (g) (intro.) and 2.;

to amend SPS 320.07 (5), (34f), (47), (50), (62) (intro.), and (66), 320.09 (5) (b) 2. d. and (6) (d), 320.24 (1), (2), (2) (Note) and (2) Tables 320.24–1 to 320.24-3, Table 320.24-4 Heading, and Tables 320.24-5 to 320.24-7 and 320.24-9 to 320.24-13, 321.02 (3) (c) and (3) (d) 1. and 2., 321.03 (1) (c) and (d), (2) (a) to (c) and (6) (d) 5. and (e) 4. and 5., (7) (a) 4., and (8) (b), and (c) 1. and 3., 321.04 (1) (a) 2., (2) (a) 1. and (c) 4. a. and b., (3) (title) to (a) 5., (b) 3. a. and b., (c) (title) to 1. a. and 2. and 3., and (4) (a) 2. and (b), 321.05 (1) (intro.), 321.08 Table 321.08, 321.125 (3) (a) 2., 321.16 (1) (a), 321.18 (1) (c) 3. a. and (d) 2. c. and (4), 321.25 Table 321.25–A footnote d, Table 321.25–I (title), and Table 321.25–J (title), 321.27 (4) (d), 321.28 (3) (a) 2., 322.21 (3) (b), 322.31 Table 322.31–4, 322.34 (2) (d), 322.38 (2) (c) 4., 323.04 Table 323.04–A footnote 5, 323.045 (6) (a) and (8) (intro.), and 323.16 (2) (a);

and to create SPS 320.02 (1) (ce), (cm), (cs), and (Notes), 320.07 (36r) and (37m), 320.24 (2) Table 320.24–12, Row 3, 321.02 (3) (d) (Note), (3) (h) 2., and (4) (Note), 321.03 (1) (b) (Note) and (h) 3., (6) (f) and (Note), and (11), 321.04 (3) (b) 1. b. to d. and (c) 1. d., and (4) (d) (title) and 2., 321.045 (4) (c) 2., 321.05 (1m), and (2) (a) 2. and (b) 1. to 3., 321.06 (1) (b) and (3) to (6), 321.08 (3) (c), 321.09 (2) (a) (Note), 321.10 (2) (f) 2.,

321.12 (title), (2), and (3), 321.15 (1) (e) 2., 321.16 (2) (d), 321.18 (1) (c) 3. d. and (d) 2. c. (Note), 321.22 (9) (a) (Note) and (b) (Note) and (10) and (Notes), 321.24 (3) (e) and (Note) and (f) and (Note), 321.25 (2m) and (3) (a) (title), 321.25 Table 321.25–I footnote j and Table 321.25–J footnote j, 321.25 (8) (a) (Note) [2], 321.26 (8) (Note), 321.28 (3) (a) 6. and (7) (c) 2., 322.01 (3) (b), 322.32 (1) (b) and (9) (b), 322.33 (1) (b) and (3) (c), 322.38 (1) (b) 2. and (2) (c) 4. (Note) and 5., 322.42 (1m), 323.04 (4) (b) and (Note) [2], 323.045 (5m) and (6) (a) (title), 323.06 (1) (d), (e), and (f), 323.14 (1) (b) and (2) (a) 1., and 325.01 (1) (title) and (2) to (4), relating to one- and two-family dwellings.

Analysis prepared by the Department of Safety and Professional Services.

ANALYSIS

Statutes interpreted:

Sections 101.63 (intro.) and (1) (intro.) and (5).

Statutory authority:

Sections 227.11 (2) (a) and 101.63 (intro.) and (1) (intro.).

Explanation of agency authority:

Section 227.11 (2) (a) of the Statutes authorizes the Department to promulgate rules interpreting any statute that is enforced or administered by the Department, if the rule is considered necessary to effectuate the purpose of the statute.

Sections 101.63 (intro.) and (1) (intro.) require the Department to adopt rules which establish standards for the construction and inspection of one- and two-family dwellings and components thereof. No set of rules may be adopted that has not taken into account the costs of specific code provisions to home buyers in relationship to the benefits derived from the provisions.

Related statute or rule:

Various other statutes and rules promulgated by the Department address construction and inspection of dwellings, public buildings and places of employment.

Plain language analysis:

These rules update and clarify the Uniform Dwelling Code to make it consistent with contemporary construction practices, products, and materials. The rules clear up confusing and ambiguous portions of the code. They clarify language relating to stairs, ramps, and landings, and accessory guards and handrails. These rules also update references to national standards and provide flexibility in meeting exiting requirements.

They establish safer standards for dryer exhaust and clarify ceiling height, foundation anchorage, and framing and fastening provisions.

Summary of, and comparison with, existing or proposed federal regulation:

An Internet-based search of the *Code of Federal Regulations* (CFR) and the *Federal Register* did not find any federal regulations relating to the rule revisions herein for one- and two-family dwellings.

Comparison with rules in adjacent states:

Illinois:

An Internet-based search did not reveal the existence of a statewide one- and two-family dwelling code. Dwelling regulation appears to be left up to the individual local units of government.

Iowa:

An internet based search revealed that the Iowa Building Code adopts the 2009 International Residential Code and 2009 International Energy Conservation Code. The Iowa Building Code applies statewide to state owned and funded buildings. The accessibility, energy conservation, and minimum plumbing provisions apply to dwellings statewide.

Michigan:

An Internet-based search revealed a mandatory, statewide one- and two-family dwelling code. The Residential Construction Code under the Construction Code Commission's General Rules, in section 408.305, contains the state amendments to the 2009 International Residential Code (IRC) developed by the International Code Council.

Minnesota:

An Internet-based search revealed a mandatory, statewide one- and two-family dwelling code. The Minnesota Department of Labor and Industry, in Chapter 1309, adopts the 2006 IRC, chapters 2-10 and 43. Chapters 2-10 contain the general construction provisions of the IRC. The state code is being revised effective June 1, 2015 and will adopt the 2015 Minnesota version of the International Residential Code developed by the International Code Council with input from Minnesota.

Summary of factual data and analytical methodologies:

The Department received input during numerous meetings with the Dwelling Code Council. The makeup of this Council is established under section 15.407 (10) of the Statutes and consists of members who are appointed by the Governor. The Council

includes representatives of several types of small businesses. Through this Council, the Department was able to gather information on the potential impacts of the rule revisions contained herein.

Analysis and supporting documents used to determine effect on small business or in preparation of economic impact analysis:

The rule revisions are not expected to significantly impact small business because they would clarify and simplify current requirements rather than impose new restrictions.

Fiscal Estimate and Economic Impact Analysis:

The Fiscal Estimate and Economic Impact Analysis are attached.

Effect on small business:

These proposed rules are not expected to have an economic impact on small businesses, as defined in s. 227.114 (1), Stats. The Department's Regulatory Review Coordinator may be contacted by email at Eric.Esser@wisconsin.gov, or by calling (608) 267-2435.

Agency contact person:

Dan Smith, Rules Coordinator, Department of Safety and Professional Services, Division of Policy Development, 1400 East Washington Avenue, Room 151, P.O. Box 8935, Madison, Wisconsin 53708; telephone 608-261-4463; email at Daniel2.Smith@wisconsin.gov.

Place where comments are to be submitted and deadline for submission:

Comments may be submitted to Dan Smith, Rules Coordinator, Department of Safety and Professional Services, Division of Policy Development, 1400 East Washington Avenue, Room 151, P.O. Box 8366, Madison, WI 53708-8935, or by email to Daniel2.Smith@wisconsin.gov. Comments must be received on or before * to be included in the record of rule-making proceedings.

TEXT OF RULE

SECTION 1. SPS 320.02 (1) (ce) and (ce) (note), (cm) and (cm) note, and (cs) and (cs) (note) are created to read:

SPS 320.02 (1) (ce) A one- or 2-family dwelling built on or after the effective dates under s. SPS 320.03 that is used as a foster home or group home, or as a residential care center for children and youth that has a capacity for 8 or fewer children, all as defined in s. 48.02, Stats. Where such a home or center is operated in each dwelling unit

of a 2-family dwelling, the capacity limit for each unit is independent of the other unit only if the two operations are independent of each other.

Note: The definitions in s. 48.02 of the Statutes limit foster homes to no more than 4 children unless the children are siblings, and limit group homes to no more than 8 children. Where permitted by the Department of Children and Families, a group home or a residential care center for children and youth that has a capacity for 8 or fewer children may be located in a one- or 2-family dwelling as a community living arrangement, as defined in s. 46.03 (22) of the Statutes.

(cm) A one- or 2-family dwelling built on or after the effective dates under s. SPS 320.03, in which a public or private day care center for 8 or fewer children is located. Where such a day care center is operated in each dwelling unit of a 2-family dwelling, the capacity limit for each unit is independent of the other unit only if the two operations are independent of each other.

Note: Chapter DCF 250, as administered by the Department of Children and Families, defines a “family child care center” as being “a facility where a person provides care and supervision for less than 24 hours a day for at least 4 and not more than 8 children who are not related to the provider.” Chapter DCF 250 applies various licensing and other requirements to these centers, including for fire protection and other aspects of the physical plant.

(cs) 1. Any portion of or space within a one- or 2-family dwelling built on or after the effective dates under s. SPS 320.03, in which a home occupation is located.

2. In this paragraph, “home occupation” means any business, profession, trade, or employment conducted in a person’s dwelling unit, that may involve the person’s immediate family or household and a maximum of one other unrelated person, but does not involve any of the following:

- a. Explosives, fireworks, or repair of motor vehicles.
- b. More than 25% of the habitable floor area of the dwelling unit.

Note: See chs. SPS 361 to 366 for buildings that are beyond the scope of this code.

SECTION 2. SPS 320.02 (5) is renumbered SPS 321.02 (4) and amended to read:

SPS 321.02 (4) ~~INNOVATIVE DWELLINGS~~ ALTERNATE MATERIALS AND STANDARDS. No part of this code is intended to prohibit or discourage use of alternate, equivalent materials or standards; or the construction of innovative dwellings such as a dwelling built below ground, a geodesic dome, a concrete house, a ~~fiber-glass~~ fiberglass house, or any other nonconventional structure.

SECTION 3. SPS 320.07 (34f) is amended to read:

SPS 320.07 (34f) “Flight” means a continuous series of ~~steps~~ risers and treads, with no intermediate landings.

SECTION 4. SPS 320.07 (34m) is repealed.

SECTION 5. SPS 320.07 (36r) and (37m) are created to read:

SPS 320.07 (36r) “Guard” means a barrier erected to prevent a person from falling to a lower level.

(37m) “Handrail” means a horizontal or sloping rail intended for grasping by a hand, for guidance or support or preventing a fall down a stair.

SECTION 6. SPS 320.07 (47), (50), (62) (intro.), and (66) are amended to read:

SPS 320.07 (47) “Landing” means the level portion of a stairs located between flights of stairs or located at the top and ~~foot~~ base of a stairs.

(50) “Loft” means an upper room or floor which has at least 50% of the common wall open to the floor below. The opening may be infringed upon by an open ~~guardrail~~ guard constructed in compliance with s. SPS 321.04 (2), but not by a window or half-wall ~~guardrail~~ guard. All habitable rooms of lofts are open to the floor below.

(62) (intro.) “Shingle” means a unit of ~~roof covering~~ roof-covering material that has been manufactured to specific dimensions and is applied in overlapping fashion. “Shingle” includes all of the following:

(66) A ~~“stairway” is~~ “Stair,” “stairs,” or “stairway” means one or more flights of ~~steps, risers and the necessary treads, platforms and landings connecting them, to which~~ steps, risers and the necessary treads, platforms and landings connecting them, to which form a continuous passage from one elevation to another. Multiple stairways can be connected by platforms and landings.

SECTION 7. SPS 320.07 (67) and (67m) are repealed.

SECTION 8. SPS 320.085 is repealed.

SECTION 9. SPS 320.09 (5) (b) 2. d. is amended to read:

SPS 320.09 (5) (b) 2. d. The location and construction details of wall bracing on each building side and floor level. The details may consist of the Wall Bracing Compliance Worksheet or a legend showing which wall bracing method is used and the

lengths or number of braced wall panels – and demarcation of the circumscribed rectangles if more than one is used.

SECTION 10. SPS 320.09 (5) (d) is repealed.

SECTION 11. SPS 320.09 (6) (d) is amended to read:

SPS 320.09 (6) (d) The name of the initial downstream receiving water of the state from the dwelling shall be identified, regarding erosion and sediment control ~~and storm water management.~~

SECTION 12. SPS 320.24 (1), (2), and (2) (Note) are amended to read:

SPS 320.24 (1) CONSENT. Pursuant to s. 227.21 (2), Stats., the attorney general has consented to the incorporation by reference of the standards listed in Tables 320.24-1 to ~~320.14-13~~ 320.24-13.

(2) ADOPTION OF STANDARDS. The standards referenced in Tables 320.24-1 to ~~320.14-13~~ 320.24-13 are incorporated by reference into this chapter.

Note: Copies of the adopted standards are on file in the offices of the department and the legislative reference bureau. Copies of the standards may be purchased, or are available for free, through the respective organizations or other information listed in Tables 320.24-1 to ~~320.14-13~~ 320.24-13.

SECTION 13. SPS 320.24 (2) Table 320.24–1 is amended to read:

SPS 320.24 (2) Table 320.24–1

ACI	American Concrete Institute P.O. Box 9094 Farmington Hills, MI 48333 www.concrete.org
Standard Reference Number	Title
1. 318-05 <u>318-14</u>	Building Code Requirements for Structural Concrete
2. <u>332-14</u>	<u>Residential Code Requirements for Structural Concrete</u>
23. 530-05 <u>530-13</u>	Building Code Requirements for Masonry Structures
34. 530.1-05 <u>530.1-13</u>	Specification for Masonry Structures

SECTION 14. SPS 320.24 (2) Table 320.24–2 is renumbered SPS 320.24 (2) Table 320.24–6m and amended to read:

SPS 320.24 (2) Table 320.24-6m

AF&PA <u>AWC</u>	American Forest & Paper Association <u>Wood Council</u> 1111 19 th Street, N.W., Suite 800
---------------------------------	--

	Washington, D.C. 20036 222 Catocin Circle SE Suite 201 Leesburg, VA 20175 www.americanwoodcouncil.org
Standard Reference Number	Title
1. NDS-2005 <u>ANSI/AWC NDS-2012</u>	National Design Specification For Wood Construction Including 2005 Supplement
2. ANSI/AF&PA <u>ANSI/AWC PWF - 2007</u>	Permanent Wood Foundation Design Specification

SECTION 15. SPS 320.24 (2) Tables 320.24-3, 320.24-4, 320.24-5 (heading), 320.24-6, and 320.24-7 are amended to read:

SPS 320.24 (2) Table 320.24-3

AISC	American Institute of Steel Construction One E. East Wacker Drive, Suite 3400 <u>700</u> Chicago, IL 60601 www.aisc.org
Standard Reference Number	Title
1. 360-05 <u>ANSI/AISC 360-10</u>	Specification for Structural Steel Buildings

Table 320.24-4

ASTM	American Society for Testing and Materials <u>ASTM International</u> 1916 Race Street Philadelphia, <u>100 Barr Harbor Drive</u> <u>PO Box C700</u> <u>West Conshohocken, PA 19403 19428-2959</u> www.astm.org
Standard Reference Number	Title
1. C 62-01 <u>C62-13a</u>	Standard Specification for Building Brick (Solid Masonry Units Made From Clay or Shale)
2. C 90-02 <u>C90-14</u>	Standard Specification for Hollow Load-Bearing <u>Loadbearing</u> Concrete Masonry Units
3. C 216-02 <u>C216-14</u>	Standard Specification for Facing Brick (Solid Masonry Units Made From Clay or Shale)
4. C 270-01a <u>C270-14</u>	Standard Specification for Mortar for Unit Masonry
5. C 476-01 <u>C476-10</u>	Standard Specification for Grout for Masonry
6. C 652-01a <u>C652-14</u>	Standard Specification for Hollow Brick (Hollow Masonry Units Made From Clay or Shale)
7. D 225-01	Standard Specification for Asphalt Shingles (Organic Felt) Surfaced With Mineral Granules
8. D 226-97a <u>7. D226-09</u>	Standard Specification for Asphalt-Saturated Organic Felt Used In Roofing And Water Proofing
9. D 3462-02 <u>8. D3462-10a</u>	Standard Specification for Asphalt Shingles Made From Glass Felt and Surfaced With Mineral Granules
10. D 4869-02 <u>9. D4869-05(2011)e1</u>	Standard Specification for Asphalt-Saturated Organic Felt Shingle Underlayment Used in Roofing

Table 320.24-5 (heading)

ASCE	American Society of Civil Engineers 1801 Alexander Bell Drive Reston, VA 20191 www.asce.org
------	--

Table 320.24-6

ASHRAE	American Society of Heating, Refrigerating, and Air-conditioning Engineers, Inc. 1791 Tullie Circle, N.E. Atlanta, GA 30329 www.ashrae.org
Standard Reference Number	Title
1. 2005 <u>2013</u> Fundamentals	ASHRAE Handbook, _ Fundamentals
2. 2003 <u>2011</u> HVAC Applications	ASHRAE <u>Handbook</u> – HVAC Applications Handbook
3. 2004 <u>2012</u> HVAC Systems & Equipment	ASHRAE <u>Handbook</u> – HVAC Systems & Equipment Handbook

Table 320.24-7

ICC	The International Code Council 500 New Jersey Avenue, NW, 6th Floor Washington, D.C. 20001 www.iccsafe.org
Standard Reference Number	Title
ICC/ANSI 400-2007 <u>ICC 400-2012</u>	Standard on the Design and Construction of Log Structures

SECTION 16. SPS 320.24 (2) Table 320.24–8 is repealed.

SECTION 17. SPS 320.24 (2) Tables 320.24–9 (heading) 320.24-10, 320.24-11 (heading) and 320.24–12 (heading) are amended to read:

SPS 320.24 (2) Table 320.24-9 (heading)

NAIMA	North American Insulation Manufacturers Association 44-11 Canal Canter Plaza, Suite 340 <u>103</u> Alexandria, VA 22314 www.naima.org
-------	---

Table 320.24-10

NFPA	National Fire Protection Association 1 Batterymarch Park Quincy, MA 02269 www.nfpa.org
Standard Reference Number	Title
1. NFPA 13D 2002 <u>2013</u>	Standard for the Installation of Sprinkler Systems in One- and

	Two-Family Dwellings and Manufactured Homes
2. ANSI Z223.1-2009/ NFPA 54-2009 <u>NFPA 54/ANSI</u> <u>Z223.1 2015</u>	National Fuel Gas Code

Table 320.24-11 (heading)

NIST	National Institute of Standards and Technology U.S. Department of Commerce Washington, D.C. 20234 http://catalog.hathitrust.org/Record/009487395
------	--

Table 320.24-12 (heading)

SMACNA	Sheet Metal and Air Conditioning Contractors <u>Contractors'</u> National Association 4201 Lafayette Center Drive Chantilly, VA 20151-1209 <u>20151-1219</u> www.smacna.org
--------	---

SECTION 18. SPS 320.24 (2) Table 320.24-12 Row 3 is created to read:

SPS 320.24 (2) Table 320.24-12
(Partial Table)

Standard Reference Number	Title
3. Third Edition, 2005	HVAC Duct Construction Standards – Metal and Flexible

SECTION 19. SPS 320.24 (2) Table 320.24-13 is amended to read:

SPS 320.24 (2) Table 320.24-13

TPI	Truss Plate Institute, Inc. 218 North Lee Street, Suite 312 Alexandria, VA 22314 www.tpinst.org
Standard Reference Number	Title
1. TPI 1-2002 <u>ANSI/TPI 1-2007</u>	National Design Standard for Metal Plate Connected Wood Truss Construction

SECTION 20. SPS 321.02 (1) (b) 1. Table 321.02 is renumbered SPS 321.02 (1) (b) 1. Table 321.02-1.

SECTION 21. SPS 321.02 (1) (d) (title) is renumbered SPS 321.02 (3) (h) (title).

SECTION 22. SPS 321.02 (1) (d) and (Note) are renumbered SPS 321.02 (3) (h) 1., and (Note), and amended to read:

SPS 321.02 (3) (h) 1. All building components shall be fastened to withstand the dead load, live load, snow load, and wind load.

Note: ~~See the Appendix for a schedule of fasteners that will be acceptable to the department for compliance with this subsection.~~ Other fastening methods may be allowed if engineered under s. SPS 321.02 (3).

SECTION 23. SPS 321.02 (3) (c) is amended to read:

SPS 321.02 (3) (c) *Structural steel.* The design, fabrication, and erection of structural steel for buildings shall conform to Specification for Structural Steel Buildings, ~~Allowable Stress Design and Plastic Design~~ and the provisions of the accompanying commentary as adopted under Table 320.24-3.

SECTION 24. SPS 321.02 (3) (d) 1. and 2. are amended to read:

SPS 321.02 (3) (d) 1. ACI Standard 318, "Building Code Requirements for Reinforced Structural Concrete".

2. ACI Standard ~~318.1~~ 332, "Building Residential Code Requirements for Structural Plain Concrete".

SECTION 25. SPS 321.02 (3) (d) (Note) is created to read:

SPS 321.02 (3) (d) Note: Concrete construction in one- and two-family dwellings should meet the standards established in ACI 332. Construction means, materials, or methods not addressed in ACI 332 should meet the standards established in ACI 318.

SECTION 26. SPS 321.02 (3) (g) (intro.) and 2. are consolidated, renumbered SPS 321.02 (3) (g), and amended to read:

SPS 321.02 (3) (g) *Whole logs.* Dwellings constructed of whole logs shall conform to ~~the following standards:~~ 2. ICC/ANSI ICC 400, Standard on the Design and Construction of Log Structures.

SECTION 27. SPS 321.02 (3) (g) 1. is repealed.

SECTION 28. SPS 321.02 (3) (h) 2. is created to read:

SPS 321.02 (3) (h) 2. Fasteners shall comply with the schedule listed in Table 321.02-2.

SECTION 29. SPS 321.02 (4) (Note) is created to read:

SPS 321.02 (4) Note: Examples of materials addressed by this subsection include structural insulated panels that are used in accordance with the manufacturer's instructions or structural analysis, and cold-formed steel framing complying with AISI S230 *Standard for Cold-Formed Steel Framing – Prescriptive Method for One and Two Family Dwellings*.

SECTION 30. SPS 321.03 (1) (b) (Note) is created to read:

SPS 321.03 (1) (b) Note: Under this paragraph, only one of the two exit doors that are addressed in par. (a) is required to exit directly to grade.

SECTION 31. SPS 321.03 (1) (c) and (d) are amended to read:

SPS 321.03 (1) (c) ~~An additional~~ Any exit that does not comply with par. (b) may discharge to an outside balcony that complies with sub. (8).

(d) ~~An additional~~ Any exit that does not comply with par. (b) may discharge into an attached garage provided the garage has an exit door that discharges to grade. An overhead garage door may not be used as an exit door.

SECTION 32. SPS 321.03 (1) (h) 3. is created to read:

SPS 321.03 (1) (h) 3. One of the exit doors required in par. (a) may be omitted for a dwelling unit that has one or more egress windows on the first floor. If there are bedrooms, each must have a window that complies with sub. (6).

SECTION 33. SPS 321.03 (2) (a) to (c) and (6) (d) 5. and (e) 4. and 5. a. are amended to read:

SPS 321.03 (2) (a) At least 2 exits shall be provided from the second floor. ~~One~~ At least one of the exits shall be a stairway or ramp and lead to the first floor or discharge to grade. The second exit may be via a stairway or ramp ~~which that~~ discharges to grade, or ~~may discharge~~ to a balcony which complies with sub. (8), or to a deck that complies with s. SPS 321.225 and that is no more than 15 feet above the grade below.

(b) ~~Except as provided in par. (c), windows~~ Windows which that comply with sub. (6) may be provided in each second floor bedroom – or in another location on the

second floor if there are no bedrooms on that floor – in lieu of the second exit from the that floor.

(c) Where the second floor of a building is the lowest floor level in a dwelling unit, as in an up-and-down duplex, ~~windows may not be provided as the second exit from the floor~~ no exit from the unit may go through another dwelling unit or other party's occupancy on the first floor.

(6) (d) 5. A ~~Step~~ stair used for the sole purpose of reaching the top of the platform or fixture is exempt from the requirements of s. SPS 321.04.

(e) 4. If the bottom of the areaway is more than 46 inches below adjacent grade or the top of the areaway enclosure, the areaway shall be provided with a ladder or ~~at least one additional step~~ stair to aid egress. ~~Steps~~ Stairs used to comply with this section are exempt from the requirements of s. SPS 321.04.

5. a. Ladders or other ~~steps~~ stairs used to comply with subd. 4. may infringe on the required area of the areaway by a maximum of 6 inches.

SECTION 34. SPS 321.03 (6) (f) and (Note) are created to read:

SPS 321.03 (6) (f) An egress window under a deck or porch shall discharge through a clear path of at least 36 inches in height and 36 inches in width, and no more than 15 feet in length, to a yard or open space.

Note: Under this paragraph, there is no maximum height above grade for an egress window. Similarly, egress windows are not prohibited from discharging to a roof, regardless of the slope of the roof.

SECTION 35. SPS 321.03 (7) (a) 4. and (8) (b), and (c) 1. and 3. are amended to read:

SPS 321.03 (7) (a) 4. Where sliding doors are used as a required exit, the clear opening shall be at least ~~30~~ 29 inches wide and be at least 76 inches high.

(8) (b) Balconies shall be provided with ~~guardrails~~ guards in accordance with s. SPS 321.04 (3).

(c) 1. The balcony ~~guardrail~~ guard shall terminate no more than 46 inches above the floor level of the balcony.

3. The floor of the balcony shall have minimum dimensions of 3 feet by 3 feet. The ~~guardrail~~ guard and its supports may infringe on the dimensions of the required area.

SECTION 36. SPS 321.03 (11) is created to read:

SPS 321.03 (11) EXITS TO COURTYARDS. No exit may discharge to a courtyard having a perimeter that is entirely enclosed by exterior building walls or other obstructions that prevent pedestrian passage.

SECTION 37. SPS 321.04 (1) (a) 2., (2) (a) 1. and (c) 4. a. and b., and (3) (title) and (a) 1. to 5. are amended to read:

SPS 321.04 (1) (a) 2. Tub access ~~steps~~ stairs, unless they are an integral part of an approved plumbing product.

(2) (a) 1. Except for spiral staircases under subd. 2., stairways shall measure at least 36 inches in width. Handrails and associated trim may project a maximum of 4.5 inches into the required width at each side of the stairway. The minimum clear width at and below the handrail, including at treads and landings, may not be less than 31.5 inches where a handrail is installed on one side, and 27 inches where handrails are provided on both sides.

(c) 4. a. An individual winder tread may be placed between rectangular treads or at the end of a flight of rectangular treads provided the tread depth is at least 9 inches, when measured at a point distance of 12 inches from the narrow end, is equal to the tread depth of the rectangular steps in the flight of the tread or from the inside face of the wall.

b. There may be more than one individual winder tread in a stairway ~~or in a flight of stairs.~~

(3) (title) HANDRAILS AND ~~GUARDRAILS~~ GUARDS.

(a) 1. ~~Stair flights~~ A flight of stairs with more than 3 risers shall be provided with at least one handrail for the full length of the ~~stair~~ flight.

2. ~~Handrails or guardrails~~ Guards shall be provided on all open sides of ~~stair flights~~ stairs consisting of more than 3 risers and on all open sides of areas that are elevated more than 24 inches above the floor or exterior grade.

Note: A handrail provided at 30 to 38 inches above the tread nosing meets the height requirement for a ~~guardrail~~ guard on a stairway.

3. a. Except as provided in subd. 3. b., ~~handrails and guardrails~~ guards shall be constructed to prevent the through-passage of a sphere with a diameter of 4 3/8 inches ~~or larger, when applying a force of 4 pounds.~~

b. The triangular area formed by the tread, riser and bottom rail shall have an opening size that prevents the through-passage of a sphere with a diameter of 6 inches ~~or larger, when applying a force of 4 pounds.~~

c. Rope, cable, or similar materials used in ~~handrail or guardrail~~ guard infill shall be strung with maximum openings of 3½ inches with vertical supports a maximum of 4 feet apart.

4. a. Handrails and ~~guardrails~~ guards shall be designed and constructed to withstand a 200 pound load applied in any direction.

b. Handrail or ~~guardrail~~ guard infill components, balusters and panel fillers shall withstand a horizontally applied perpendicular load of 50 pounds on any one-foot-square area.

c. Glazing used in handrail or ~~guardrail~~ guard assemblies shall be safety glazing.

5. Exterior handrails and ~~guardrails~~ guards shall be constructed of metal, decay resistant or pressure-treated wood, or shall be protected from the weather.

SECTION 38. SPS 321.04 (3) (b) 1. is renumbered SPS 321.04 (3) (b) 1. a. and amended to read:

SPS 321.04 (3) (b) 1. a. Handrails shall be located at least 30 inches, but no more than 38 inches above the nosing of the treads, except as provided in subds. 1. b. to d. Measurement shall be taken from the hard structural surface beneath any finish material to the top of the rail. Variations in uniformity are allowed only when a rail contacts a wall or newel post or where a turnout or volute is provided at the bottom ~~step~~ tread.

SECTION 39. SPS 321.04 (3) (b) 1. b. to d. are created to read:

SPS 321.04 (3) (b) 1. b. A volute, turnout, or starting easing that does not comply with subd. 1. a. may extend over the lowest tread.

c. Transition fittings on handrails may extend above the 38-inch height limit.

d. Where handrail fittings or bendings are used to provide a continuous transition between flights, or at winder treads, or from a handrail to a guard, or at the start of a flight, the height at the fittings or bendings may exceed 38 inches.

SECTION 40. SPS 321.04 (3) (b) 3. a. and b. and (c) (title) and 1. a. are amended to read:

SPS 321.04 (3) (b) 3. 'Winders.' a. Except as provided under subd. 3. b., the required handrail on winder ~~steps~~ stairs shall be placed on the side where the treads are wider.

b. Where all winder ~~steps~~ treads in a flight have a ~~tread~~ depth of at least 9 inches from nosing to nosing measured at a point 12 inches from the narrow end of the tread, the required handrail may be located on either side of the stairway.

(c) (title) ~~Guardrails~~ Guards.

1. a. All openings between floors, and open sides of landings, platforms, balconies or porches that are more than 24 inches above grade or a floor shall be protected with ~~guardrails~~ guards.

SECTION 41. SPS 321.04 (3) (c) 1. d. is created to read:

SPS 321.04 (3) (c) 1. d. This paragraph does not apply to window wells, egress wells, and retaining walls.

SECTION 42. SPS 321.04 (3) (c) 2. and 3. and (4) (a) 2. and (b) are amended to read:

SPS 321.04 (3) (c) 2. ‘Height.’ ~~Guardrails~~ Guards shall ~~be located~~ extend to at least 36 inches above the floor or to the underside of a stair handrail complying with s. SPS 321.04 (3) (b). Measurement shall be taken from the hard structural surface beneath any finish material to the top of the ~~rail~~ guard.

3. ‘Opening size.’ ~~Guardrails~~ Guards shall be constructed to prevent the through-passage of a sphere with a diameter of 4 $\frac{3}{8}$ inches ~~or larger, when applying a force of 4 pounds~~.

(4) (a) 2. Intermediate landings that connect 2 or more straight flights of stairs, or 2 flights of stairs at a right angle, shall be at least as wide as the stairway treads and shall measure at least 36 inches in the direction of travel.

(b) *Landings at the top and base of stairs.* A level landing shall be provided at the top and base of every stairs except as provided in par (d). The landing shall be at least as wide as the stairs treads and shall measure at least 3 feet in the direction of travel.

SECTION 43. SPS 321.04 (4) (c) 1. is renumbered SPS 321.04 (4) (c), and SPS 321.04 (4) (c) (intro.) and 3., as renumbered, are amended to read:

SPS 321.04 (4) (c) (intro.) *Doors at landings.* Except as provided in ~~subd. subs.~~ subd. subs. 1. ~~a. to e.~~ 3. and par. (d), level landings shall be provided on each side of any door located at the top or base of a ~~stairs~~ stair, regardless of the direction of swing. In the following exceptions, ~~stairways to a stairway between a dwelling and an attached garages garage,~~ carports carport or porches are porch is considered to be an interior stairs stair:

3. A landing is not required between a sliding glass door or an in-swinging glass door and the top of an exterior stairway of 3 or fewer risers.

SECTION 44. SPS 321.04 (4) (c) 2. is renumbered SPS 321.04 (4) (d) 1. and amended to read:

SPS 321.04 (4) (d) 1. The exterior landing, platform, or sidewalk at an exterior doorway shall be located a maximum of 8 inches below the interior floor elevation, be sloped away from the doorway at a minimal rate that ensures drainage, and shall have a length of at least 36 inches in the direction of travel out of the dwelling.

SECTION 45. SPS 321.04 (4) (d) (title) and 2. are created to read:

SPS 321.04 (4) (d) (title) *Exterior landings.*

2. The landing at the base of an exterior stair shall be sloped away from the stair at a minimal rate that ensures drainage.

SECTION 46. SPS 321.045 (4) (c) is renumbered SPS 321.045 (4) (c) 1. and amended to read:

SPS 321.045 (4) (c) 1. Open-sided ramps shall have the area below the handrail protected by intermediate rails or an ornamental pattern to prevent the passage of a sphere with a diameter of 4 $\frac{3}{8}$ inches or larger when applying a force of 4 pounds, except as provided in subd. 2.

SECTION 47. SPS 321.045 (4) (c) 2. is created to read:

SPS 321.045 (4) (c) 2. This paragraph does not apply to ramps having a walking surface that is less than 24 inches above adjacent grade, if a toe-kick or side rail is provided to 4 inches above the walking surface, and a mid-rail is provided between the toe-kick or side rail and the handrail.

SECTION 48. SPS 321.05 (1) (intro.) is amended to read:

SPS 321.05 (1) (intro.) NATURAL LIGHT. ~~All~~ Each habitable ~~rooms~~ room shall be provided with natural light by means of glazed openings. The area of the glazed openings shall be at least 8% of the net floor area, except under the following circumstances:

SECTION 49. SPS 321.05 (1m) is created to read:

SPS 321.05 (1m) NET FLOOR AREA. For the purposes of subs. (1) and (2), “net floor area” does not include any area with a ceiling height of less than 5 feet.

SECTION 50. SPS 321.05 (2) (a) is renumbered SPS 321.05 (2) (a) 1. and amended to read:

SPS 321.05 (2) (a) 1. Natural ventilation shall be provided to ~~all~~ each habitable ~~rooms~~ room by means of openable doors, skylights or windows. The net area of the openable doors, skylights or windows shall be at least 3.5% of the net floor area of the room, except as provided in subd. 2. Balanced mechanical ventilation may be provided in lieu of openable exterior doors, skylights or windows provided the system is capable of providing at least one air change per hour of fresh outside air while the room is occupied. Infiltration may not be considered as make-up air for balancing purposes.

SECTION 51. SPS 321.05 (2) (a) 2. is created to read:

SPS 321.05 (2) (a) 2. Any area with a ceiling height of less than 5 feet may be excluded from the net floor area.

SECTION 52. SPS 321.05 (3) (intro.) and (a) to (d) are renumbered SPS 321.05 (3) (am) (intro.) and 1. to 4. and SPS 321.05 (3) (a) (intro.), 1. (intro.), and a., as renumbered, are amended to read:

SPS 321.05 (3) (am) (intro.) Except as provided in par. ~~(e)~~ (b), glazing shall consist of safety glass meeting the requirements of ~~CPSC either~~ 16 CFR, Part 1201 or ANSI Z97.1 when installed in any of the following locations:

1. (intro.) In any sidelight or glazing adjacent to a door, that meets all of the following:

a. The nearest point of the glazing is within 2 feet of the door when the door is in the closed position.

SECTION 53. SPS 321.05 (3) (e) is renumbered SPS 321.05 (3) (bm) (intro.) and amended to read:

SPS 321.05 (3) (bm) (intro.) Safety glass is not required where ~~the size of an individual pane of glass is 8 inches or less in the least dimension.~~ glazing meets any of the following:

SECTION 54. SPS 321.05 (3) (bm) 1. to 3. are created to read:

SPS 321.05 (3) (bm) 1. The size of an individual pane of glass is 8 inches or less in the least dimension.

2. The safety glass is required by sub. (3) (am) 1. and the only door within 2 feet of the glazing is the fixed panel of a patio door.

3. The safety glass is required by sub. (3) (am) 1. and there is an intervening wall or other permanent barrier between the door and the glazing.

SECTION 55. SPS 321.05 (3) (a) 5. is created to read:

SPS 321.05 (3) (a) 5. In guard assemblies.

SECTION 56. SPS 321.06 is renumbered SPS 321.06 (intro.), (1) (a), and (2), and amended to read:

SPS 321.06 Ceiling height. All habitable rooms, kitchens, hallways, bathrooms and corridors shall have a ceiling height of at least 7 feet. ~~Habitable rooms, except as follows:~~

(1) (a) Rooms may have ceiling heights of less than 7 feet provided at least 50% of the room's floor area has a ceiling height of at least 7 feet. Any area with a ceiling height of less than 5 feet may be ignored in this calculation.

(2) Beams and girders or other projections ~~shall not~~ may project to no more than 8 inches below the required ceiling height.

SECTION 57. SPS 321.06 (1) (b) and (3) to (6) are created to read:

SPS 321.06 (1) (b) The 50% limit in par. (a) does not apply to subs. (3) to (6).

(3) The ceiling height extending back from the front edge of a water closet may slope to below 7 feet, but may not go below 5 feet until beyond the back of the water closet.

(4) The ceiling height extending back from the front edge of a lavatory may be less than 7 feet, but may not go below 5 feet until beyond the back of the lavatory.

(5) A ceiling height of less than 7 feet may be provided between the rear rim of a bathtub and a wall of the room abutting that rim, or between the side rim and a room wall abutting that rim.

(6) A ceiling height of less than 7 feet may be provided between the rear wall of a shower stall and a wall of the room abutting that rear wall, or between the side wall of a shower and a room wall abutting that side wall.

Note: Section SPS 384.20 (5) (o) 4. establishes minimum horizontal clearances for water closets, and reads as follows: “A water closet may not be located closer than 15 inches from its center to any side wall, partition, vanity, or other obstruction, nor closer than 30 inches center to center, between water closets. There shall be at least 24 inches clearance in front of a water closet to any wall, fixture or door.”

Note: See ch. SPS 384 Appendix for further explanatory material.

SECTION 58. SPS 321.08 Table 321.08 is amended to read:

SPS 321.08 Table 321.08

Between Dwelling And:	Distance Between Objects¹	Fire Rated Construction^{2,5}
Detached garage, or accessory building on same property	Less than 5 feet	3/4-hour wall ³ 1/3-hour door or window ³
Another dwelling on same property	Less than 5 feet	3/4-hour wall ⁴ 1/3-hour door or window ⁴
Detached garage, accessory building, or other dwelling on same property	5 to 10 feet	3/4-hour wall ³ No requirement on openings <u>1/3-hour door or window³</u>
Detached garage, accessory building, or other dwelling on same property	More than 10 feet	No requirements
Property Lines	Less than 3 feet	3/4-hour wall 1/3-hour door or window
Property Lines	3 feet or more	No requirements
Zero Lot Line	None	Follow sub. (2) (d) requirements

¹ Distance shall be measured perpendicular from wall to wall or property line, ignoring overhangs.

² Fire rated construction shall protect the dwelling from an exterior fire source.

³ Fire rated construction may be in either facing wall.

⁴ Fire rated construction shall be in both facing walls.

⁵ The methods for garage separation in par. (a) 1. are examples of ¾ hour wall construction.

SECTION 59. SPS 321.08 (3) (c) is created to read:

SPS 321.08 (3) (c) *Plastic Piping*. Penetrations of a required separation by plastic pipe shall be protected by a penetration firestop system approved by the department and installed as tested in accordance with ASTM E 814 or UL 1479, with a minimum positive pressure differential of 0.01 inch of water (3 pa), and shall have an F rating of not less than the required fire-resistance rating of the assembly penetrated.

SECTION 60. SPS 321.09 (2) (a) (Note) is created to read:

SPS 321.09 (2) (a) Note: Wireless interconnectivity is permitted under this paragraph.

SECTION 61. SPS 321.10 (2) (f) is renumbered SPS 321.10 (2) (f) 1.

SECTION 62. SPS 321.10 (2) (f) 2. is created to read:

SPS 321.10 (2) (f) 2. Siding and sheathing in contact with concrete or masonry and within 2 inches above an impervious surface.

SECTION 63. SPS 321.12 is renumbered SPS 321.12 (1) and amended to read:

SPS 321.12 (1) GRADE. The finished grade of the soil shall slope away from the dwelling at a rate of at least ~~½-inch~~ ½ inch per foot for ~~a minimum distance of at least 10 feet, or to the lot line, whichever is less~~ except as provided in subs. (2) and (3).

SECTION 64. SPS 321.12 (title), (2), and (3) are created to read:

SPS 321.12 (title) Drainage.

(2) OTHER SURFACES. Where the finished surface is impervious, it shall slope away from the dwelling for at least 10 feet at a rate that ensures equivalent drainage.

(3) OBSTRUCTIONS. Where lot lines, walls, slopes, or other barriers prevent having the 10-foot distance in sub. (2), swales or other means shall be provided to ensure equivalent drainage away from the dwelling.

SECTION 65. SPS 321.125 (3) (a) 2. is amended to read:

SPS 321.125 (3) (a) 2. Seven and ½ tons per acre per year where silt, silty clay loam, or silt loam textures are exposed.

SECTION 66. SPS 321.125 (3) (a) 2. (Note) and (b) are repealed.

SECTION 67. SPS 321.126 is repealed.

SECTION 68. SPS 321.15 (1) (e) is renumbered SPS 321.15 (1) (e) 1. and amended to read:

SPS 321.15 (1) (e) 1. Structures supported on floating slabs or similar shallow foundations may not be physically attached to structures that are supported by footings that extend below the frost line unless an isolation joint is used between the structures, except as provided in subd. 2. This isolation shall extend for the full height of the structure.

SECTION 69. SPS 321.15 (1) (e) 2. is created to read:

SPS 321.15 (1) (e) 2. Exterior ramps are not required to comply with subd. 1.

SECTION 70. SPS 321.16 (1) (a) is amended to read:

SPS 321.16 (1) (a) ~~Except as allowed under sub. (2),~~ Footings and foundations, including those for ~~ramps~~ landings and stoops, shall be placed below the frost penetration level or at least 48 inches below adjacent grade, whichever is deeper, except as allowed under sub. (2).

SECTION 71. SPS 321.16 (2) (d) is created to read:

SPS 321.16 (2) (d) Subsection (1) (a) does not apply to the footing for a ramp and its handrail posts unless the ramp abuts a frost-protected stoop or landing, in which case only the footing for that abutting end of the ramp is required to have the frost protection under sub. (1) (a), such as by bearing onto the stoop or landing, so that a tripping hazard is not created.

SECTION 72. SPS 321.18 (1) (c) 3. a. is amended to read:

SPS 321.18 (1) (c) 3. a. Structural steel anchor bolts, at least ½ inch in diameter, embedded at least 7 inches into the ~~concrete or~~ concrete or grouted masonry with a maximum spacing of 72 inches and located within 18 inches of wall corners.

SECTION 73. SPS 321.18 (1) (c) 3. d. is created to read:

SPS 321.18 (1) (c) 3. d. Alternate foundation anchorage, designed and spaced in accordance with structural analysis and as required to provide equivalent anchorage to the requirements of subd. 3a., is allowable.

SECTION 74. SPS 321.18 (1) (d) 2. c. is amended to read:

SPS 321.18 (1) (d) 2. c. Fastening of the blocking or bridging shall be in accordance with structural analysis or the fastener ~~table printed schedule in the appendix to this code~~ Table 321.02-2.

SECTION 75. SPS 321.18 (1) (d) 2. c. (Note) is created to read:

SPS 321.18 (1) (d) 2. c. Note: The floor-framing elements required in this section are intended to provide lateral support to the top of the foundation wall. See s. SPS 321.22 (9) for further requirements relating to floor framing, including for bridging of floor framing to provide restraint against rotation or lateral displacement of the floor framing.

SECTION 76. SPS 321.18 (4) is amended to read:

SPS 321.18 (4) WOOD FOUNDATIONS. Wood foundations shall be designed and constructed in accordance with the wood-foundation standard adopted in Table ~~320.24-2~~ 320.24-6m.

SECTION 77. SPS 321.22 (9) (a) (Note) and (b) (Note) and (10) and (10) (Notes) are created to read:

SPS 321.22 (9) (a) Note: This 4:1 ratio means bridging is required for wood-framed floors having nominal 2X10 or deeper solid-sawn-lumber joists, to provide restraint against rotation or lateral displacement.

(b) Note: See s. SPS 321.18 (1) (d) for further requirements relating to floor framing, including for bridging or blocking of floor framing to provide lateral support to the top of foundation walls.

(10) SILL PLATES. All of the following requirements apply to a sawn-lumber sill plate with uniform loading that is partially extended beyond the load-bearing surface of a foundation wall in order to put the exterior surface of an upper-lying wall flush with or beyond the exterior surface of insulation that is placed on the outside of the foundation wall:

(a) The center of any anchor bolt shall be set back from the side edge of the sill plate by a distance of at least 4 times the diameter of the bolt.

(b) The thickness of the concrete or mortar cover around any anchor bolt shall comply with ACI 318 section 7.7.

Note: Under ACI 318 section 7.7, the minimum cover for a 5/8-inch-diameter or smaller bolt is 1 1/2 inches.

(c) With wood floor joists that are parallel to the foundation wall, the sill plate may not extend beyond the load-bearing surface of the wall by more than one-half of the nominal thickness of the joist that bears on the sill plate.

Note: As used throughout this chapter and in the standards that the chapter incorporates by reference, the shorter side of the cross-sectional area of a wood member is the thickness of the member. The longer side of the cross-sectional area is the depth, when the longer side is vertical; and it is the width when the longer side is horizontal.

Note: Under sub. (6), wood floor joists that are perpendicular to the foundation wall can extend beyond the foundation wall by a distance of up to the depth of the joist.

Note: Subsection (1) (d) requires a full-width sill plate for floor joists over open-core masonry units.

SECTION 78. SPS 321.24 (3) (e) and (Note) and (f) and (Note) are created to read:

SPS 321.24 (3) (e) For a roof that intersects with an upper-lying head wall and rake wall, such as where a dormer is provided, the vertical metal flashing along the rake wall shall extend down the roof at least one-half inch past the vertical flashing on the head wall.

Note: A head wall as addressed in this paragraph intersects a sloping roof at a horizontal line along the top of a roof segment. A rake wall intersects a sloping roof along the side of a roof segment.

(f) For a roof eave that intersects with a sidewall, the end of the roof flashing shall be installed so that it diverts water away from the sidewall and onto the roof or into the gutter.

Note: See s. SPS 321.26 (8) for further requirements relating to flashing for masonry.

SECTION 79. SPS 321.25 (2m) is created to read:

SPS 321.25 (2m) BOTTOM PLATES. (a) *Masonry foundation walls with open top course.* 1. Where a masonry foundation wall has an open top course, a bottom plate at least as wide as the foundation wall shall be fastened to the foundation.

2. Where anchor bolts are used on a masonry foundation wall with an open top course, the minimum width of an individual piece making up the bottom plate shall be at least 5 1/2 inches.

Note: A sill plate can be made of multiple pieces to achieve the full width.

(b) *Extension beyond the bearing surface.* All of the following requirements apply to a sawn-lumber sill plate with uniform loading that is partially extended beyond the load-bearing surface of a foundation wall in order to put the exterior surface of an

upper-lying wall flush with or beyond the exterior surface of insulation which is placed on the outside of the foundation wall:

1. The center of any anchor bolt shall be set back from the side edge of the sill plate by a distance of at least 4 times the diameter of the bolt.

2. The thickness of the concrete or mortar cover around any anchor bolt shall comply with ACI 318 section 7.7.

Note: Under ACI 318 section 7.7, the minimum cover for a 5/8-inch-diameter or smaller bolt is 1 1/2 inches.

3. Where a stud wall bears directly on a double bottom plate, the plate may not extend more than 1 1/2 inches beyond the load-bearing surface of the foundation wall.

4. Where a stud wall bears directly on a single bottom plate, the plate may not extend more than 1 inch beyond the load-bearing surface of the foundation wall.

SECTION 80. SPS 321.25 (3) (intro.), (a), and (b) are renumbered SPS 321.25 (3) (am), (bm), and (cm).

SECTION 81. SPS 321.25 (3) (am) (title) is created to read:

SPS 321.25 (3) (am) (title) Headers.

SECTION 82. SPS 321.25 Table 321.25–A footnote d, Table 321.25–I (title), and Table 321.25–J (title) are amended to read:

SPS 321.25 Table 321.25–A footnote ^d~~Unless supported by structural analysis, use~~Use of stud heights that range from over 10 feet to 12 feet is limited to where all of the following conditions are met: snow loads do not exceed 25 psf; tributary dimensions for floors and roofs do not exceed 6 feet; spans for floors and roofs do not exceed 12 feet; eave projections do not exceed 2 feet; the bending modulus of elasticity is at least 1,600,000 lbf per square inch; the allowable fiber stress in bending for the wood is not less than 1310 psi as determined by multiplying the AF&PA NDS tabular base design value by the repetitive use factor, and by the size factor for all species except southern pine; utility, standard, stud, and No. 3 grade lumber of any species is not used; and the for bearing and exterior nonbearing walls is prohibited unless supported by structural analysis. The allowable deflection ~~does~~ may not exceed whichever of the following are applicable:

Interior walls and partitions — span height/180.

Exterior walls with plaster or stucco finish — span height/360.

Exterior walls with other brittle finishes — span height/240.

Exterior walls with flexible finishes — span height/120.

Exterior walls with interior gypsum wallboard finish — span height/180.

Any manufacturer-specified limits for any included windows or doors.

Table 321.25–I (Title)

**REQUIRED NUMBER OF INTERMITTENT BRACED WALL PANELS ON
WALLS PARALLEL TO EACH RECTANGLE SIDE AT EACH FLOOR
LEVEL^{a,b,c,d,e,f,h,j}**

**Table 321.25–J (Title)
REQUIRED LENGTH OF CONTINUOUS BRACING ON WALLS PARALLEL
TO EACH RECTANGLE SIDE AT EACH FLOOR LEVEL^{a,b,c,d,e,g,h,j}**

SECTION 83. SPS 321.25 Table 321.25–I footnote j and Table 321.25–J footnote j are created to read:

SPS 321.25 Table 321.25–I footnote^j Any floor, habitable or otherwise, that is contained wholly within the roof rafters or roof trusses is exempt from being considered a floor for purposes of determining wall bracing if the top-of-wall-to-ridge height does not exceed 20 feet and if no opening in the roof exceeds 48 inches in height.

Table 321.25–J footnote^j Any floor, habitable or otherwise, that is contained wholly within the roof rafters or roof trusses is exempt from being considered a floor for purposes of determining wall bracing if the top-of-wall-to-ridge height does not exceed 20 feet and if no opening in the roof exceeds 48 inches in height.

SECTION 84. SPS 321.25 (8) (a) (Note) [2] is created to read:

SPS 321.25 (8) (a) (Note) [2]: For a walk-out basement where some of the walls are concrete and other walls or portions thereof are wood-framed, the Department considers a minimum 8-inch-nominal-thickness poured-in-place concrete basement wall as being equivalent in lateral load and shear resistance to any of the allowable wood-framed wall bracing materials. To determine the required bracing for a walk-out basement, first draw a rectangle around the entire floor plan and projections as if all of the walls are wood-framed. Determine the required bracing amounts per the chosen bracing material and method and then locate the bracing to meet the requirements of Figure 321.25-C. Any required braced wall panel locations that occur on a wall or portion of a wall that is actually of poured-in-place concrete construction is considered equivalent, and that amount of bracing will count towards the minimum required amount and will not need to be provided in another location on that rectangle side.

SECTION 85. SPS 321.26 (8) (Note) is created to read:

SPS 321.26 (8) Note: See s. SPS 321.24 (3) for further requirements relating to flashing for masonry.

SECTION 86. SPS 321.27 (4) (d) is amended to read:

SPS 321.27 (4) (d) Bearing. The required bearing for wood rafters shall be in accordance with the NDS adopted in Table ~~320.24-2~~ 320.24-6m, except in no case shall the bearing be less than 1½ inches on wood or metal or less than 3 inches on masonry or concrete.

SECTION 87. SPS 321.28 (3) (a) 2. is amended to read:

SPS 321.28 (3) (a) 2. Each shingle package shall be labeled by the manufacturer to indicate conformance to the applicable ASTM standard for each type of shingle or the exception in par. ~~(e)~~ (b).

SECTION 88. SPS 321.28 (3) (a) 6. is created to read:

SPS 321.28 (3) (a) 6. All fasteners for shingles shall be corrosion-resistant.

SECTION 89. SPS 321.28 (3) (a) (Note) [2] and (b) are repealed

SECTION 90. SPS 321.28 (7) (c) is renumbered to (7) (c) (intro.) and 1. and amended to read:

SPS 321.28 (7) (c) *Flashing of closed valleys.* Where shingles are laced or woven over the valley, the valley shall be flashed with ~~at~~ one of the following:

1. At least one layer of 50-pound roofing, at least 20 inches wide, over a layer of number 15 roofing underlayment.

SECTION 88. SPS 321.28 (7) (c) 2. is created to read:

2. A product labeled as meeting the requirements of ASTM D1970.

SECTION 91. SPS 322.01 (3) is renumbered SPS 322.01 (3) (a).

SECTION 92. SPS 322.01 (3) (b) is created to read:

SPS 322.01 (3) (b) The vapor retarder requirements under s. SPS 322.38 do not apply to an unheated space, such as an attached, unheated garage.

SECTION 93. SPS 322.01 (3) (Note) is repealed.

SECTION 94. SPS 322.21 (3) (b) is amended to read:

SPS 322.21 (3) (b) The protective covering shall cover the exposed exterior insulation and extend a minimum of 6 2 inches below grade, except the covering is not required below a brick ledge.

SECTION 95. SPS 322.31 Table 322.31-1 is amended to read:

**TABLE 322.31-1
INSULATION AND FENESTRATION REQUIREMENTS BY COMPONENT^a**

Zone	Fenestration U-Factor	Skylight U-Factor	Ceiling R-Value	Wood Frame Wall R-Value	Mass Wall R-Value ⁱ	Floor R-Value	Basement or Crawl Space Wall R-Value ^b	Crawl Space Wall R-Value ^b	Heated Slab R-Value ^c	Unheated Slab R-Value ^d
1	0.35	0.60	49 ^e	19^f 20 ^f or 13+5 ^g	15/19	30 ^h	10/13 15/19	10/13	10/15	10
2	0.35	0.60	49 ^e	21 ^f	19/21	30^h 38 ^h	10/13 15/19	10/13	10/15	10

^a R-values are minimums. U-factors are maximums.

^b The first R-value applies to continuous insulation. The second R-value applies to framing cavity insulation. Either insulation meets the requirement.

^c The first R-value applies under the entire slab, regardless of depth below grade. The second R-value applies to the slab edge where the bottom of the slab is less than 12 inches below adjacent grade. Slab edge insulation shall extend downward from the top of the slab for a minimum of 48 inches or downward to at least the bottom of the slab and then horizontally to the interior or exterior for a minimum total distance of 48 inches. Also, see s. SPS 321.16 for protection against frost for slabs with supports less than 4 feet below grade.

^d The R-value applies to any slab, the bottom of which is less than 12 inches below adjacent grade. Also, see s. SPS 321.16 for protection against frost for slabs with supports less than 4 feet below grade.

^e See s. SPS 322.32 (1) for application and permitted reduced R-value.

^f ~~R-19~~ R-20 and R-21 may be compressed into a 2X6 cavity.

^g "13+5" means R-13 cavity insulation plus R-5 insulated sheathing. If structural sheathing covers 25% or less of the exterior, insulating sheathing is not required where structural sheathing is used. If structural sheathing covers more than 25% of the exterior, structural sheathing shall be covered with insulated sheathing of at least R-2.

^h Or insulation sufficient to fill the framing cavity with a minimum of R-19.

ⁱ The second R-value applies when more than half of the insulation is on the interior of the mass wall.

SECTION 96. SPS 322.31 Table 322.31-2 is amended to read:

**TABLE 322.31-2
EQUIVALENT U-FACTORS**

Zone	Fenestration U-Factor	Skylight U-Factor	Ceiling U-Factor	Wood Frame Wall U-Factor	Mass Wall U-Factor	Floor U-Factor	Basement Wall U-Factor	Crawl Space Wall U-Factor	Unheated Slab U-Factor
1	0.35	0.60	0.026	0.060 0.057	0.060 ^a	0.033	0.065 0.050	0.065	10
2	0.35	0.60	0.026	0.057	0.057 ^a	0.033 0.028	0.065 0.050	0.065	10

^a When more than half the insulation is on the interior, the mass wall U-factors shall be the same as the frame wall U-factor.

SECTION 97. SPS 322.31 Table 322.31-4 is amended to read:

**TABLE 322.31-4
COMPONENT DWELLING THERMAL ENVELOPE REQUIREMENTS
FOR DWELLINGS USING LOWER EFFICIENCY APPLIANCES^a**

Fenestration U-Factor	Skylight U-Factor	Ceiling R-Value	Wood Frame Wall R-Value	Mass Wall R-Value	Floor R-Value	Basement or Crawl Space Wall R-Value ^b	Heated Slab R-Value ^c	Unheated Slab R-Value ^d
0.30	0.60	49 ^e	21 ^f or 19+5 ^g	19	30 ^h	15/19	10/20	15
Equivalent U-Factors								
0.30	0.60	0.26* 0.026	0.057	0.057	0.033	0.045	0.033	0.047

* ~~Note: The correct number is .026. An error was discovered in the rule order after completion of the rule-making process.~~

^a R-values are minimums. U-factors are maximums.

^b The first R-value applies to continuous insulation. The second R-value applies to framing cavity insulation.

^c The first R-value applies under the entire slab, regardless of depth below grade. The second R-value applies to the slab edge. Slab edge insulation shall extend downward from the top of the slab for a minimum of 48 inches or downward to at least the bottom of the slab and then horizontally to the interior or exterior for a minimum total distance of 48 inches.

^d The R-value applies to the slab perimeter insulation, where the bottom of the slab is less than 12 inches below adjacent grade. Slab edge insulation shall extend downward from the top of the slab for a minimum of 48 inches or downward to at least the bottom of the slab and then horizontally to the interior or exterior for a minimum total distance of 48 inches. Also, see s. SPS 321.16 for protection against frost for slabs with supports less than 4 feet below grade.

^e See s. SPS 322.32 (1) for application and permitted reduced R-value.

^f R-21 may be compressed into a 2X6 cavity.

^g "19+5" means R-19 cavity insulation plus R-5 insulated sheathing. If structural sheathing covers 25% or less of the exterior, insulating sheathing is not required where structural sheathing is used. If structural sheathing covers more than 25% of the exterior, structural sheathing shall be covered with insulated sheathing of at least R-2.

^h Or insulation sufficient to fill the framing cavity with a minimum of R-19.

SECTION 98. SPS 322.31 Table 322.31-4 (Note) is repealed:

SECTION 99. SPS 322.31 (2) (b) (Note) is amended to read:

SPS 322.31 (2) (b) Note: The downloadable version of REScheck 4.2.2 4.6.1, Wisconsin 2009 Code, meets the requirements of this code.

SECTION 100. SPS 322.32 (1) is renumbered SPS 322.32 (1) (a).

SECTION 101. SPS 322.32 (1) (b) is created to read:

SPS 322.32 (1) (b) An attic-access cover shall be weatherstripped and insulated to a level equivalent to the insulation on the surrounding surfaces when the attic is an unconditioned space. A wood framed or equivalent baffle or retainer is required to be provided when loose fill insulation is installed, the purpose of which is to prevent loose fill insulation from spilling into the living space when the attic access is opened, and to provide a permanent means of maintaining the installed R-value of the loose fill insulation.

SECTION 102. SPS 322.32 (3) (b) is repealed.

SECTION 103. SPS 322.32 (3) (title) and (a) are consolidated, renumbered, and amended to read:

SPS 322.32 (3) MASS WALLS. ~~(a) The requirements of Table 322.31-1 are applicable in a to mass wall walls where at least 50 percent of the required insulation R-value is on the exterior of, or integral to, the wall.~~

SECTION 104. SPS 322.32 (9) is renumbered SPS 322.32 (9) (a).

SECTION 105. SPS 322.32 (9) (b) is created to read:

SPS 322.32 (9) (b) The vertical and flared walls in a skylight shall meet the insulation requirements for walls. Tube skylights shall be insulated per the manufacturer's recommendations.

SECTION 106. SPS 322.33 (1) is renumbered SPS 322.33 (1) (a) and amended to read:

SPS 322.33 (1) (a) Any heated or unheated slab floor, the bottom of which is less than 12 inches below adjacent grade, shall be provided with perimeter insulation in accordance with Table 322.31-1 or Table 322.31-4, except as provided in par. (b).

SECTION 107. SPS 322.33 (1) (b) and (3) (c) are created to read:

SPS 322.33 (1) (b) At the threshold or the base of any door opening that leads directly to the exterior of the structure, the vertical perimeter insulation shall be at least R-5, excluding all garage doors.

(3) (c) Insulation on a foundation wall for a basement may be interrupted at the junction with a foundation wall.

SECTION 108. SPS 322.34 (2) (d) is amended to read:

SPS 322.34 (2) (d) The edges of the vapor retarder shall extend at least 6 inches up the foundation wall and shall be attached and sealed to the foundation wall or insulation.

SECTION 109. SPS 322.37 (6) (intro), (a) 1. to 7. and (b) are created to read:

SPS 322.37 (6) COMPLIANCE DEMONSTRATION. Building envelope air tightness and insulation installation shall be demonstrated to comply with one of the following options:

(a) *Testing option.* Building envelope tightness and insulation installation shall be considered acceptable when tested air leakage is less than seven air changes per hour (ACH) when tested with a blower door at a pressure of 33.5 psf (50 Pa). Testing shall occur after rough in and after installation of penetrations of the building envelope, including penetrations for utilities, plumbing, electrical, ventilation and combustion appliances. During testing all of the following shall be done:

1. Exterior windows and doors, fireplace and stove doors shall be closed, but not sealed;

2. Dampers shall be closed, but not sealed, including exhaust, intake, makeup air, backdraft and flue dampers;

3. Interior doors shall be open;

4. Exterior openings for continuous ventilation systems and heat recovery ventilators shall be closed and sealed;

5. Heating and cooling system(s) shall be turned off;

6. HVAC ducts shall not be sealed; and

7. Supply and return registers shall not be sealed.

(b) *Visual inspection option.* Building envelope tightness and insulation installation shall be considered acceptable when the items listed in Table 332.37, applicable to the method of construction, are field verified. Where required by the code official, an approved party independent from the installer of the insulation shall inspect the air barrier and insulation.

SECTION 110. SPS 322.37 (6) Table 322.37 is created to read:

TABLE 332.37

AIR BARRIER AND INSULATION INSPECTION COMPONENT CRITERIA

COMPONENT	CRITERIA
Air barrier and thermal barrier	Exterior thermal envelope insulation for framed walls is installed in substantial contact and continuous alignment with building envelope air barrier.

	Breaks or joints in the air barrier are filled or repaired. Air-permeable insulation is not used as a sealing material. Air-permeable insulation is inside of an air barrier.
Ceiling/attic	Air barrier in any dropped ceiling/soffit is substantially aligned with insulation and any gaps are sealed. Attic access (except unvented attic), knee wall door, or drop down stair is sealed.
Walls	Corners and headers are insulated. Junction of foundation and sill plate is sealed.
Windows and doors	Space between window/door jambs and framing is sealed.
Rim joists	Rim joists are insulated and include an air barrier.
Floors (including above-garage and cantilevered floors)	Insulation is installed to maintain permanent contact with underside of subfloor decking. Air barrier is installed at any exposed edge of insulation.
Crawl space walls	Insulation is permanently attached to walls. Exposed earth in unvented crawl spaces is covered with Class I vapor retarder with overlapping joints taped.
Shafts, penetrations	Duct shafts, utility penetrations, knee walls and flue shafts opening to exterior or unconditioned space are sealed.
Narrow cavities	Batts in narrow cavities are cut to fit, or narrow cavities are filled by sprayed/blown insulation.
Garage separation	Air sealing is provided between the garage and conditioned spaces.
Recessed lighting	Recessed light fixtures are air tight, IC rated, and sealed to drywall. Exception-fixtures in conditioned space.
Plumbing and wiring	Insulation is placed between outside and pipes. Batt insulation is cut to fit around wiring and plumbing, or sprayed/blown insulation extends behind piping and wiring.
Shower/tub on exterior wall	Showers and tubs on exterior walls have insulation and an air barrier separating them from the exterior wall.
Electrical/phone box on exterior walls	Air barrier extends behind boxes or air sealed-type boxes are installed.
Common wall	Air barrier is installed in common wall between dwelling units.
HVAC register boots	HVAC register boots that penetrate building envelope are sealed to subfloor or drywall.
Fireplace	Fireplace walls include an air barrier.

SECTION 111. SPS 322.38 (1) (b) is renumbered SPS 322.38 (1) (b) 1. and amended to read:

SPS 322.38 (1) (b) 1. The vapor retarder shall be continuous. All joints in a vapor retarder consisting of sheet material shall be overlapped 6 inches and taped or

sealed, except as provided in subd. 2. Rips, punctures, and voids in the vapor retarder shall be patched with vapor retarder materials and taped or sealed. Seams that are not over a framing member shall be taped or sealed.

SECTION 112. SPS 322.38 (1) (b) 2. is created to read:

SPS 322.38 (1) (b) 2. Taping or sealing a vapor retarder is not required around doors and windows, behind bathtub enclosures, and at top and bottom wall plates, if the retarder is held to those materials in an airtight manner by other building components, such as gypsum wallboard.

SECTION 113. SPS 322.38 (2) (c) 4. is amended to read:

SPS 322.38 (2) (c) 4. No vapor retarder is required over cavities that ~~are insulated solely with~~ have at least 50% of the required R-value provided by spray-applied foam having a perm rating of 1.0 or less, unless required by the foam manufacturer.

SECTION 114. SPS 322.38 (2) (c) 4. (Note) is repealed.

SECTION 115. SPS 322.38 (2) (c) 5. is created to read:

SPS 322.38 (2) (c) 5. A vapor retarder for a floor over an open, unheated area may consist of 5/8-inch tongue-and-groove oriented-strand board, or 3/4-inch tongue-and-groove CDX plywood, which is exposure-rated plywood.

SECTION 116. SPS 322.42 (1m) is created to read.

SPS 322.42 (2) Cooling supply ducts that pass through unconditioned spaces conducive to condensation, such as attics, shall be provided with insulation having a thermal resistance of at least R-8. The exterior of that insulation shall be covered with a vapor retarder that meets the requirements in s. SPS 322.38 (1)

SECTION 117. SPS 322.43 (7) (intro) and 1. and 2. and (8) are created to read:

SPS 322.43 (7) Except where exempted as indicated in par. (8), duct tightness shall be verified by either of the following:

1. Postconstruction test: Leakage to outdoors shall be less than or equal to 8 cfm per 100 ft² of conditioned floor area or a total leakage less than or equal to 12 cfm per 100 ft² of conditioned floor area when tested at a pressure differential of 0.1 inches w.g.

(25 Pa) across the entire system, including the manufacturer's air handler enclosure. All register boots shall be taped or otherwise sealed during the test.

2. Rough-in test: Total leakage shall be less than or equal to 6 cfm per 100 ft² of conditioned floor area when tested at a pressure differential of 0.1 inches w.g. (25 Pa) across the roughed in system, including the manufacturer's air handler enclosure. All register boots shall be taped or otherwise sealed during the test. If the air handler is not installed at the time of the test, total leakage shall be less than or equal to 4 cfm per 100 ft² of conditioned floor area.

(8) A duct tightness test is not required if the air handler and all ducts are located within conditioned space.

SECTION 118. SPS 322.44 and (title) are renumbered 322.44, (title) and (3).

SECTION 119. SPS 322.44 (1) and (2) are created to read:

SPS 322.44 (1) Mechanical system piping capable of carrying fluids above 105°F (41°C) or below 55°F (13°C) shall be insulated to a minimum of R-3.

(2) All circulating service hot water piping shall be insulated to at least R-2. Circulating hot water systems shall include an automatic or readily accessible manual switch that can turn off the hotwater circulating pump when the system is not in use.

SECTION 120. SPS 322.47 (title), and (1) and (2) are created to read:

SPS 322.47 Equipment requirements. (1) Mechanical ventilation outdoor air intakes and exhausts shall have automatic or gravity dampers that close when the ventilation system is not operating.

(2) Snow melt system controls. Snow- and ice-melting systems, supplied through energy service to the building, shall include automatic controls capable of shutting off the system when the pavement temperature is above 50°F, and no precipitation is falling and an automatic or manual control that will allow shutoff when the outdoor temperature is above 40°F.

SECTION 121. SPS 322.48 (title), (intro), and (1), (2) (title) and (a) to (c), and (3) (title) and (a) and (b) are created to read:

SPS 322.48 Indoor Pools. Indoor pools shall be provided with energy-conserving measures in accordance with all of the following:

(1) POOL HEATERS. All pool heaters shall be equipped with a readily accessible on-off switch to allow shutting off the heater without adjusting the thermostat setting. Pool heaters fired by natural gas shall not have continuously burning pilot lights.

(2) TIME SWITCHES. (a) Except where allowed in pars. (b) and (c), time switches that can automatically turn off and on heaters and pumps according to a preset schedule shall be installed on swimming pool heaters and pumps.

(b) Where public health standards require 24-hour pump operation, time switches are not required.

(c) Where pumps are required to operate solar- and waste-heat-recovery pool heating systems, time switches are not required.

SECTION 122. SPS 322.49 is created to read:

SPS 322.49 Lighting Equipment. A minimum of 50 percent of the lamps in permanently installed lighting fixtures shall be high-efficacy lamps.

SECTION 123. SPS 323.04 Table 323.04–A footnote 5 is amended to read:

SPS 323.04 Table 323.04–A footnote ⁵To combustible material or metal cabinets. If the underside of such combustible material or metal cabinet is protected with asbestos millboard at least 1/4-inch thick covered with sheet metal of not less than No. 28 gauge, the distance may be not less than 24 inches. Also, if the manufacturer of the range, cooktop, or cooking stove specifies a shorter clearance, that clearance may be used instead.

SECTION 124. SPS 323.04 (4) is renumbered SPS 323.04 (4) (a).

SECTION 125. SPS 323.04 (4) (b) and (Note) [2] are created to read:

SPS 323.04 (4) (b) Solid fuel-fired water-heating appliances installed inside one or two family dwellings are exempt from the requirements of s. SPS 341.49 (3).

Note [2]: The appliances addressed in this section include non-pressurized solid-fuel-fired water-heating appliances used for space heating.

SECTION 126. SPS 323.045 (5) (a) is renumbered SPS 323.045 (5).

SECTION 127. SPS 323.045 (5m) is created to read:

SPS 323.045 (5m) MOUNTING ON THE GROUND. Ground-based solid-fuel-burning appliances shall be installed in accordance with the manufacturer's specifications.

SECTION 128. SPS 323.045 (6) (a) (title) is created to read:

SPS 323.045 (6) (a) (title) *General*.

SECTION 129. SPS 323.045 (6) (a) (intro.) is renumbered SPS 323.045 (6) (a) and amended to read:

SPS 323.045 (6) (a) Solid-fuel-burning appliances shall be installed with clearances not less than specified in Table 323.045-D, except as provided in pars. (b) and (c).

SECTION 130. SPS 323.045 (6) (a) 1. and 2. are renumbered SPS 323.045 (6) (b) and (c).

SECTION 131. SPS 323.045 (8) (intro.) is amended to read:

SPS 323.045 (8) (intro.) SUPPLEMENTAL UNITS. Supplemental solid-fuel-burning units connected to a furnace shall be connected to the warm air side of the furnace as illustrated in Figures 323.045-C to E-, and shall be installed in accordance with all of the following:

SECTION 132. SPS 323.06 (1) (d) to (f) are created to read:

SPS 323.06 (1) (d) Listed fireplace stoves are not required to comply with this section if permitted in the manufacturer's instructions.

(e) Masonry fireplaces shall conform to the requirements of s. SPS 321.29.

(f) Listed factory-built fireplaces shall comply with the manufacturer's recommendations and shall conform with the requirements of s. SPS 321.32.

SECTION 133. SPS 323.14 (1) is renumbered SPS 323.14 (1) (a).

SECTION 134. SPS 323.14 (1) (b) is created to read:

SPS 323.14 (1) (b) Plastic pipes and fittings used in venting flue gas shall bear the manufacturer's identification data.

SECTION 135. SPS 323.14 (2) (a) is renumbered SPS 323.14 (2) (a) 2. and amended to read:

SPS 323.14 (2) (a) 2. Gas-fired clothes dryers shall be provided with metal venting ~~that terminates outside the structure.~~

SECTION 136. SPS 323.14 (2) (a) 1. is created to read:

SPS 323.14 (2) (a) 1. All venting for clothes dryers, including for electric dryers, shall be rigid and smooth-walled. The connection to the dryer shall be made in accordance with the manufacturer's recommendations.

SECTION 137. SPS 323.16 (2) (a) is amended to read:

SPS 323.16 (2) (a) The total oil storage capacity inside any dwelling unit shall be limited to 550 gallons in one tank, or not more than 275 gallons in each of 2 tanks cross-connected to a single burner.

SECTION 138. SPS 325.01 is renumbered SPS 325.01 (1) and amended to read:

SPS 325.01 (1) The design, construction, and installation of plumbing shall comply with the requirements of the Wisconsin Plumbing Code, chs. SPS 382 to 387, except as provided in this section.

SECTION 139. SPS 325.01 (1) (title) and (2) to (4) are created to read:

SPS 325.01 (title) GENERAL.

(2) TANKLESS WATER HEATERS. (a) The minimum flow rate of a tankless type water heater may be obtained by multiplying 0.65 by the calculated hot water gallons per minute demand, as determined by SPS 382 Tables 382.40-1b and 382.40-3, provided the heater will achieve a water temperature of 110° F at the terminal fitting or faucet.

(b) The sizing method in par. (a) may not be used for sizing a water heater serving a high-flow fixture, a hose bibb, a hydrant, or a fixture that is required to have a supply line with a diameter larger than one-half inch.

(c) For the purposes of this subsection, “high-flow fixture” means a fixture with a flow rate of more than 4 gallons per minute, at 80 pounds per square inch, and a water velocity not exceeding 8 feet per second.

(3) LOCAL WASTE PIPING. A trap may be omitted in local waste piping having a length of up to 20 feet.

(4) FLOOR DRAINS FOR GARAGES. (a) A trap may be omitted for a garage-floor drain that discharges to the ground surface.

(b) The sediment trap for a garage-floor drain shall be removable.

(c) The grate for a garage-floor drain may be nonmetallic if it has a thickness and strength that will withstand the anticipated loads.

SECTION 140. SPS 320 to 325 Appendix, Minimum Fastener Schedule Table is renumbered SPS 321.02 (3) (h) Table 321.02-2 and amended to read:

**SPS 321.02 (2) (h) Table 321.02-2
MINIMUM FASTENER SCHEDULE TABLE**

Other interior and exterior panel products and finishes installed per manufacturer requirements. For engineered connectors, use manufacturer’s specified fasteners.

Description of Building Materials/Connection	Number and Type of Fastener ^{1 2 3}
Floor Framing	
Joist to joist, face nailed over support	2-12d <u>3-8d</u>
Joist to sill or girder, toe nail	2-16d, 3-8d
Band or rim joist to joist, end nail	3-16d
Band or rim joist to sill or top plate	2-16d at 16” o.c.
Bridging to joist, toe nail each end	2-8d
Built-up girder and beams, top loaded	10d at 32” o.c. at top and bottom and staggered and two at ends and at each splice
Built-up girder and beams, side-loaded	16d at 16” o.c. at top and bottom and staggered and two at ends and at each splice
Ledger strip to beam, face nail	3-16d each joist
Joist on ledger to beam, toe nail	3-8d
Wall Framing	
Sole plate to joist or blocking, face nail	2-16d at 16” o.c.
Top or sole plate to stud, end nail	2-16d
Stud to sole plate, toe nail	4-8d <u>3-8d</u> or 3-16d <u>2-16d</u>
Doubled studs, face nail	16d <u>10d</u> at 24” o.c.
Doubled top plates, face nail	16d <u>10d</u> at 16” <u>24”</u> o.c.
<u>Doubled top plates, minimum 24-inch offset of end joints, face nail in lapped area</u>	<u>8-16d</u>
Top plates, laps and intersections, face nail	2-16d <u>2-10d</u>

Continuous header, two pieces	16d at 16" o.c. along each edge
Continuous header to stud, toe nail	4-8d
1" corner brace to each stud and plate, face nail	2-8d or 2 staples, 1 ³ / ₄ "
Built-up corner studs	16d at 30" o.c., 16d 10d at 24" o.c.
Roof/Ceiling Framing	
Ceiling joists to plate, toe nail	2-16d , 3-8d
Ceiling joist, laps over partitions, face nail	3-16d <u>3-10d</u>
Ceiling joist to parallel rafters, face nail	3-16d
Rafter to plate, toe nail (maximum 6 rafter span, engineered connector for longer)	2-16d, 3-8d
Roof rafters to ridge, valley or hip rafters, toe nail	4-16d
Roof rafters to ridge, valley or hip rafters, face nail	3-16d
Collar ties to rafters, face nail	3-8d
Boards and planks	
1" x 6" subfloor or less to each joist, face nail	2-8d or 2 staples, 1 ³ / ₄ "
Wider than 1" x 6" subfloor toe to each joist, face nail	3-8d or 4 staples 1 ³ / ₄ "
2" subfloor to joist or girder, blind and face nail	2-16d
1" x 6" roof or wall sheathing to each bearing, face nail	2-8d or 2 staples, 1 ³ / ₄ "
1" x 8" roof or wall sheathing to each bearing, face nail	2-8d or 3 staples, 1 ³ / ₄ "
Wider than 1" x 8" roof sheathing to each bearing, face nail	3-8d or 4 staples, 1 ³ / ₄ "
2" planks	2-16d at each bearing

Panel Sheathing

Material	Fastener	Spacing of Fastener	
		Edges	Intermediate Supports
Engineered wood panel for sub-floor and roof sheathing and wall corner wind bracing to framing			
⁵ / ₁₆ " to ¹ / ₂ "	6d common or deformed nail or staple, 1 ¹ / ₂ "	6"	12" ⁴
⁵ / ₈ " to ³ / ₄ "	8d smooth or common, 6d deformed nail, or staple, 1 ³ / ₄ "	6"	12" ⁴
⁷ / ₈ " to 1"	8d common or deformed nail	6"	12"
1 ¹ / ₈ " to 1 ¹ / ₄ "	10d smooth or common, or 8d deformed nail	6"	12"
Combination subfloor/underlayment to framing			
³ / ₄ " or less	6d deformed or 8d smooth or common nail	6"	12"
⁷ / ₈ " to 1"	8d smooth, common or deformed nail	6"	12"
1 ¹ / ₈ " to 1 ¹ / ₄ "	10d smooth or common or 8d deformed nail	6"	12"
Wood panel siding to framing			
¹ / ₂ " or less	6d corrosion-resistant siding and casing nails	6"	12"
⁵ / ₈ "	8d corrosion-resistant siding and casing nails	6"	12"
¹ / ₂ " structural cellulosic fiberboard sheathing	1 ¹ / ₂ " galvanized roofing nail; 8d common nail; staple 16 ga., 1 ¹ / ₂ " long	3"	6"
²⁵ / ₃₂ " structural cellulosic fiberboard sheathing	1 ³ / ₄ " galvanized roofing nail; 8d common nail; staple 16 ga., 1 ³ / ₄ " long	3"	6"
¹ / ₂ " gypsum sheathing ⁵	1 ¹ / ₂ " galvanized roofing nail; 6d common nail; staple galvanized 1 ¹ / ₂ " long; 1 ¹ / ₄ " screws, Type W or S	4"	8"
⁵ / ₈ " gypsum sheathing	1 ³ / ₄ " galvanized roofing nail; 8d common nail; staple galvanized 1 ⁵ / ₈ " long; 1 ⁵ / ₈ " screws, Type	7"	7"

- ¹ All nails are smooth-common, box or deformed shank except where otherwise stated.
- ² Nail is a general description and may be T-head, modified round head or round head.
- ³ Staples are 16-gauge wire, unless otherwise noted, and have a minimum $\frac{7}{16}$ " o.d. crown width.
- ⁴ Staples shall be spaced at not more than 10" o.c. at intermediate supports for floors.
- ⁵ Apply vertically 4' x 8' or 4' x 9' panels.

NOTE to LRB: Remove Fastener Schedule from the UDC Appendix Table of Contents

SECTION 141. EFFECTIVE DATE. The rules adopted in this order shall take effect on the first day of the month following publication in the Wisconsin administrative register, pursuant to s. 227.22 (2) (intro.), Stats.

(END OF TEXT OF RULE)

Dated _____ Agency _____
(Member of the Board or Secretary)
(board or department name)