

Insert pages for September
1, 2014 Wisconsin
Commercial Building Code,
SPS 361-366, into
the International Energy
Conservation Code, 2009
edition

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366, into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 1, Insert 1A, Page 1 of 1
Insert before page 1

SPS 363.001 Purpose. This chapter regulates the design and construction of buildings for the effective use of energy. This chapter provides flexibility to permit the use of innovative approaches and techniques to achieve the effective use of energy. This chapter is not intended to abridge safety, health or environmental requirements contained in other applicable codes.

SPS 363.002 Application. (1) MIXED OCCUPANCY. Where a building includes both residential and commercial occupancies, each occupancy shall be separately considered and meet the applicable provisions of IECC chapter 4 for residential or IECC chapter 5 for commercial.

(2) EXEMPT BUILDINGS AND STRUCTURES. Glazed structures or glazed portions of buildings used for the production of plant life or for maintaining plant life as the primary purpose are exempt from the building thermal envelope provisions of this code, provided that glazed portions are separated from the remainder of the building by building thermal envelope assemblies complying with this chapter.

SPS 363.0100 Changes, additions or omissions to IECC. Changes, additions or omissions to the IECC are specified in this subchapter and are rules of the department and are not requirements of the IECC.

Note: The sections in this chapter are generally numbered to correspond to the numbering used in the IECC, i.e., s. SPS 363.0101 refers to section IECC 101.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 1, Insert 1B, Page 1 of 1
Insert between pages 2 and 3

SPS 363.0101 Administration and enforcement. Except for IECC section 101.5.2, the requirements in IECC sections 101 and 103 to 109 are not included as part of this chapter.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 1, Insert 1C, Page 1 of 1
Insert between pages 4 and 5

SPS 363.0101 Administration and enforcement. Except for IECC section 101.5.2, the requirements in IECC sections 101 and 103 to 109 are not included as part of this chapter.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 2, Insert 2A, Page 1 of 1
Insert between pages 4 and 5

SPS 363.0202 General definitions. (2) SUBSTITUTIONS. Substitute the following definition for the corresponding definition listed in IECC section 202: “Approved” has the meaning given in s. SPS 362.0202 (2).

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 2, Insert 2B, Page 1 of 1
Insert between pages 6 and 7

SPS 363.0202 General definitions. (1) ADDITIONS. This is a department definition for this chapter in addition to the definitions in IMC section 202: “Effective aperture” or “EA” means for windows, the visible light transmittance times the window wall ratio per wall; and for sky lights, the well efficiency times the visible light transmittance times the sky light area times 0.85 divided by the gross exterior roof area.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366, into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 3, Insert 3A, Page 1 of 3
Insert between pages 24 and 25

SPS 363.0302 Exterior design conditions. These are department rules in addition to the requirements in IECC section 302: The exterior design temperatures used for heating and cooling load calculations shall be as specified under Table 363.0302.

Table 363.0302
Exterior Design Conditions

County	Winter	Summer	
	Design Temp (F)	Dry Bulb (_F)	Wet Bulb (_F)
Adams	-20	87	75
Ashland	-25	86	70
Barron	-25	86	75
Bayfield	-25	86	70
Brown	-15	87	75
Buffalo	-20	87	75
Burnett	-25	86	75
Calumet	-15	87	75
Chippewa	-25	86	75
Clark	-20	87	75
Columbia	-15	87	75
Crawford	-15	87	75
Dane	-15	87	75
Dodge	-15	87	75
Door	-15	87	75
Douglas	-25	86	70
Dunn	-25	86	75
Eau Claire	-20	87	75
Florence	-25	86	75
Fond du Lac	-15	87	75
Forest	-25	86	75
Grant	-15	87	75
Green	-15	87	75
Green Lake	-15	87	75
Iowa	-15	87	75

IECC Chapter 3, Insert 3A, Page 2 of 3

Iron	-25	86	70
Jackson	-20	87	75
Jefferson	-10	89	77
Juneau	-20	87	75
Kenosha	-10	89	77
Kewaunee	-15	87	75
La Crosse	-20	87	75
Lafayette	-15	87	75
Langlade	-20	87	75
Lincoln	-25	86	75
Manitowoc	-15	87	75
Marathon	-20	87	75
Marinette	-20	87	75
Marquette	-15	87	75
Menominee	-20	87	75
Milwaukee	-10	89	77
Monroe	-20	87	75
Oconto	-20	87	75
Oneida	-25	86	75
Outagamie	-15	87	75
Ozaukee	-10	89	77
Pepin	-20	87	75
Pierce	-25	86	75
Polk	-25	86	75
Portage	-20	87	75
Price	-25	86	75
Racine	-10	89	77
Richland	-15	87	75
Rock	-10	89	77
Rusk	-25	86	75
St Croix	-25	86	75
Sauk	-15	87	75
Sawyer	-25	86	75
Shawano	-20	87	75
Sheboygan	-15	87	75
Taylor	-25	86	75
Trempeleau	-20	87	75
Vernon	-20	87	75
Vilas	-25	86	75

IECC Chapter 3, Insert 3A, Page 3 of 3

Walworth	-10	89	77
Washburn	-25	86	75
Washington	-10	89	77
Waukesha	-10	89	77
Waupaca	-20	87	75
Waushara	-15	87	75
Winnebago	-15	87	75
Wood	-20	87	75

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366, into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 3, Insert 3B, Page 1 of 1
Insert between pages 24 and 25

SPS 363.0303 Materials, systems and equipment. These are department rules in addition to the requirements in IECC section 303.

(1) GENERAL. Except as specified in sub. (2), when available, information on thermal properties, performance of building envelope sections, and components and heat transfer shall be obtained from ASHRAE Handbook of Fundamentals.

(2) EXCEPTIONS. (a) When the information is not available from ASHRAE Handbook of Fundamentals, the data shall be obtained from laboratory or field-test measurements. If laboratory or field test measurements are used for envelope heat transmission, the measurements shall be obtained using one of the following test methods:

1. ASTM C177, Test method by guarded hot plate apparatus.
2. ASTM C335, Test method of horizontal pipe insulation.
3. ASTM C518, Test method by means of the heat flow meter apparatus.
4. ASTM C1363, Test method by means of a hot box apparatus.

(b) For foam plastic insulation that incorporates a substance other than air as the insulating medium, laboratory or field tests shall be conducted on representative samples that have been aged for the equivalent of 5 years or until the R-Value has stabilized to determine thermal properties or performance. The tests shall be conducted by an independent third party.

(c) Integrally insulated concrete masonry systems within the scope of the National Concrete Masonry Association (NCMA) shall be evaluated for the thermal performance of the masonry or concrete units in accordance with one of the following:

1. NCMA Evaluation Procedures for the Integrally-Insulated Concrete Masonry Walls.
2. Default values as approved by the department.

(d) All other concrete or masonry units not within the scope of the NCMA Evaluation Procedures shall comply with one of the following methods for determining the thermal performance of the assembly or system:

1. Default values as approved by the department.
2. Laboratory or field-test measurements specified in par. (a).
3. Department material approval process as specified in ch. SPS 361 to determine the U-factor.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366, into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 4, Insert 4A, Page 1 of 1
Insert between pages 26 and 27

SPS 363.0401 Certificate. The requirements in IECC section 401.3 are not included as part of this code.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 4, Insert 4B, Page 1 of 1
Insert between pages 30 and 31

SPS 363.0403 Systems. (1) ELECTRICAL POWER AND LIGHTING. This is a department rule in addition to the requirements in IECC section 403: In residential buildings having individual dwelling units, provisions shall be made to determine the electrical energy consumed by each tenant by separately metering individual dwelling units.

(2) DUCTS. Substitute the following wording for the requirements in IECC section 403.2.2: All ducts, air handlers, and filter boxes shall be sealed. Joints and seams shall comply with IMC section 603.9.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services IECC

Chapter 4, Insert 4C, Page 1 of 1
Insert between pages 32 and 33

SPS 363.0405 Calculation software tools. This is a department informational note to
be used under IECC section 405.6:

Note: The federal Department of Energy has developed REScheck™, a computer program
that may be used in demonstrating compliance for a residential building which has no more
than 3 stories above grade and has 3 or more dwelling units. The REScheck program may be
downloaded at <http://www.energycodes.gov/>. When using the program, the applicable code
must be defined as the “2009 IECC.” The use of the “Wisconsin” option will apply
requirements associated with a 1 or 2 family dwelling, which are more restrictive than those
associated with low-rise multifamily buildings.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5A, Page 1 of 1
Insert between pages 36 and 37

SPS 363.0501 General application. This is a department rule in addition to the requirements in IECC section 501.2: All of the following rules shall apply regardless of whether the IECC chapter 5 or ASHRAE 90.1 standard is used to determine compliance:

- (1) Section SPS 363.0503 (1) relating to design loads.
- (2) Sections SPS 363.0503 (3) and (4) relating to economizers.
- (3) Section SPS 363.0505 relating to lighting systems.
- (4) IECC section 505.2.2.1 relating to dual switching.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366, into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5B, Page 1 of 1
Insert between pages 42 and 43

SPS 363.0503 Building mechanical systems. (1) CALCULATION OF HEATING AND COOLING LOADS. The following wording is a department requirement in addition to the requirements in IECC section 503.2.1: Design heating and cooling loads shall be determined in accordance with s. SPS 363.0302 and Table 363.0302.

(2) EQUIPMENT AND SYSTEM SIZING. Substitute the following wording for the requirements and the exceptions in IECC section 503.2.2: Heating and cooling equipment and systems shall be sized to provide the minimum space and system loads calculated in accordance with s. SPS 363.0302.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5C, Page 1 of 1
Insert between pages 50 and 51

SPS 363.0503 Building mechanical systems. (3) HVAC SYSTEM COMPLETION.
The requirements in IECC sections 503.2.9 to 503.2.9.3 are not included as part of this
chapter.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366, into the International Energy Conservation Code, 2009 edition

Industry Services - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5D, Page 1 of 1
Insert between pages 52 and 53

SPS 363.0503 Building mechanical systems. (4) ECONOMIZERS SIMPLE HVAC SYSTEMS. Substitute the following wording for the requirements in IECC section 503.3.1 the first paragraph and Table 503.3.1 (1): Supply air economizers shall be provided on the following cooling systems: (a) Package roof top units > 33,000Btu/h.
(b) All other cooling systems > 54,000 Btu/h.

(5) ECONOMIZERS COMPLEX HVAC SYSTEMS. Substitute the following wording for the requirements, but not the exceptions, in IECC section 503.4.1: Supply air economizers shall be provided on cooling systems as described under sub. (4). Economizers shall be capable of operating at 100 percent outside air, even if additional mechanical cooling is required to meet the cooling load of the building.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366, into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5E, Page 1 of 1
Insert between pages 54 and 55

SPS 363.0503 Building mechanical systems. (6) CLIMATE ZONES 3 AND 4. [See Editor's Note Below.] Substitute the following wording for the requirements in IECC section 503.4.3.3.2.2: For climate Zones 5 through 8 as indicated in Figure 301.1 and Table 301.1, if an open-circuit cooling tower is used, then a separate heat exchanger shall be required to isolate the cooling tower from the heat pump loop, and heat loss shall be controlled by shutting down the circulation pump on the cooling tower loop and providing an automatic valve to stop the flow of fluid.

Editor's Note: Error - The title of (6) should be "Climate Zones 5 through 8."

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5F, Page 1 of 1
Insert between pages 54 and 55

SPS 363.0504 Service water heating. (1) TEMPERATURE CONTROLS. The requirements in IECC section 504.3 are not included as part of this chapter.
(2) HEAT TRAPS. The requirements in IECC section 504.4 are not included as part of this chapter.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5G, Page 1 of 1
Insert between pages 56 and 57

SPS 363.0504 Service water heating. 3) POOL COVERS. The requirements in IECC
section 504.7.3 are not included as part of this chapter.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366, into the International Energy Conservation Code, 2009 edition

Industry Services - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5H, Page 1 of 1
Insert between pages 56 and 57

SPS 363.0505 Lighting systems. (1) CONTROLS. These are department rules in addition to the requirements in IECC section 505:

(a) *General.* Except as provided in par. (b), daylight zones in any interior enclosed space greater than 250 square feet and a lighting density more than 0.6 W/ft² shall have at least one control that meets all of the following requirements:

1. Controls only luminaires in the daylight zones.
2. Controls at least 50% of the lamps or luminaires in the daylight zone, in a manner described in IECC section 505.2.2.1.

(b) *Exceptions.* The requirements of this subsection do not apply to any of the following:

1. Daylight zones where the effective aperture of glazing is equal or less than 0.1 for vertical glazing and 0.01 for horizontal glazing.
2. Daylight zones where existing adjacent structures or natural objects obstruct daylight to the extent that effective use of daylighting is not feasible.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5I, Page 1 of 1
Insert between pages 56 and 57

SPS 363.0501 General application. This is a department rule in addition to the requirements in IECC section 501.2: All of the following rules shall apply regardless of whether the IECC chapter 5 or ASHRAE 90.1 standard is used to determine compliance:
(4) IECC section 505.2.2.1 relating to dual switching.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366, into the International Energy Conservation Code, 2009 edition

Industry Services - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5J, Page 1 of 1
Insert between pages 58 and 59

SPS 363.0505 Lighting systems. (2) LINE-VOLTAGE LIGHTING TRACK AND PLUG-IN BUSYWAY. Substitute the following for the requirements in IECC section 505.5.1.4: The wattage of line-voltage lighting track and plug-in busway which allows the addition or relocation of luminaires without altering the wiring of the system shall be the volt-ampere rating of the branch circuit feeding the luminaires or an integral current limiter controlling the luminaires, or the higher of the maximum relamping rated wattage of all of the luminaires included in the system, listed on a permanent factory installed label, or 30 W/linear foot.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366,
into the International Energy Conservation Code, 2009 edition

Industry Services Division - Wisconsin Department of Safety and Professional Services

IECC Chapter 5, Insert 5K, Page 1 of 1
Insert between pages 60 and 61

SPS 363.0506 Total building performance. This is a department informational note to
be used under IECC section 506:

Note: ComCheck is a computer program that may be used only for determining building
envelope or lighting compliance. The ComCheck computer program may be downloaded at:
<http://www.energycodes.gov/>.

Insert pages for September 1, 2014, Wisconsin Commercial Building Code, SPS 361-366, into the International Energy Conservation Code, 2009 edition

Industry Services - Wisconsin Department of Safety and Professional Services

IECC Chapter 6, Insert 6A, Page 1 of 1
Insert between pages 70 and 71

SPS 363.0900 Referenced standards. This is a department rule in addition to the requirements in IECC chapter 6: The following standards are hereby incorporated by reference into this code:

(1) ASTM C 177-04, Test method for steady-state heat flux measurements and thermal transmission properties by means of the guarded-hot-plate apparatus.

(2) ASTM C 335-05, Test method for steady state heat transfer properties of horizontal pipe insulation.

(3) ASTM C518-04, Test Method for steady-state thermal transmission properties by means of the heat flow meter apparatus.

(4) ASTM C1363-05, Test method for thermal performance of materials and envelope assemblies by means of a hot box apparatus.

(5) National Concrete Masonry Association (NCMA) Evaluation Procedures of Integrally Insulated Concrete Masonry Walls, January 1, 1999.

Note: ASTM standards may be purchased from the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103. NCMA Evaluation Procedures may be obtained from the National Concrete Masonry Association, 2302 Horse Pen Road, Herndon, VA 20171-3499. Copies of the standards adopted under this section are on file in the offices of the department, the legislative reference bureau.