



Traps & Connections

62. **SPS 382.32(3)(a) - 2/25/04**

May a garbage disposal be installed on a breakroom sink? Yes. There are no requirements prohibiting the installation of a garbage disposal on a breakroom sink.

73. **SPS 82.32(4)(b) - 6/1/06**

Is a pedestal pedicure spa considered a pedestal fixture? Yes. A pedestal pedicure spa may be installed in accordance with the pedestal fixture requirement for vertical distance from the fixture outlet to the trap.